



Helping to keep the lights on,
businesses running
and communities strong

2017 10-Year Assessment Preliminary Study Design


November 2, 2016

Stakeholder and Customer Webcast


Purpose

- **Solicit Study Design Input**
 - 2017 Assessment Process
 - 2017 Assessment Assumptions
 - Public Policy Requirements
- **Project List Update Proposal**

ATC Transmission Planning Process



Project Status



Strategic


Provisional

Proposed

Planned

In-Service

Assessment Process



Planning Criteria & Assessment Practices

- NERC Standards, particularly TPL-001, version 4
- ATC Planning Criteria/Assessment Practices
 - <http://www.atc10yearplan.com> (About tab)
 - To be updated after the November FERC audit

Public Policy Requirements

- Following Attachment FF Processes
- Previously identified requirements
 - State Renewable Portfolio Standard (RPS) mandates
 - EPA regulations
 - State mandates and goals for energy efficiency (EE) and demand side management (DSM) programs
- For the 2017 10-Year Assessment, assessing combined impacts using:
 - Expected load forecasts from LSEs
 - Confirmed generation additions
 - Confirmed generation retirements
 - Multiple year analysis over a range load levels
 - Minimum
 - Shoulder
 - Peak
 - High Load Sensitivity
- Any public policy driven needs that may not be covered by the Assessment process?

Model Years

- 2017 (As-planned)
 - 2018
 - 2022
 - 2027
-
- All models will likely be completed by the Spring of 2017


Load - Historical

- Requested September 28, 2016
 - Summer peak
 - Winter peak
 - Light load
 - Shoulder load
- Receive November 1, 2016
- Add to databases

Load – Expected Forecast

- Requested LDC forecasts February 2016
 - 11 years
 - Consistent with resource planning forecast
 - Considered expected (50/50 probability)
- Received in April 2016
- ATC compiles
 - Comparisons to previous forecasts
 - Differences confirmed with LDCs
 - Finalized copy to LDCs – September 2016
 - Forecasted load is what the system is planned for

Load Forecast Trends



Generation Modeling

- Existing generator data
 - Annual updates requested from GOs in Q3 of each year
- Generation additions
 - Only add generators with signed interconnection agreements
 - Additions modeled at MISO Facility study location
 - MISO queue suspended generators with signed IAs
 - included in after 18 months
- Generation retirements
 - generators with a completed MISO Attachment Y are modeled as retired, unless there is an SSR agreement

Generation Dispatch

- **Local Balancing Area merit order dispatch:**
 - Used for Assessment summer peak and shoulder models. Local Balancing Area dispatch from merit order provided by LBA
- **ATC-wide merit order dispatch:**
 - Minimum load models
 - ATC-wide merit order dispatch determined with PROMOD
- **Generators without scheduled transactions:**
 - If signed IA,
 - generation included in the host Local Balancing Area.
- **Wind Farms**
 - Align with MISO MTEP models:
 - Peak: 16%
 - Off-peak: 40%
 - Historical
 - Peak: ~25%
 - Off-Peak
 - Shoulder: ~30%
 - Minimum: ~35%

Reactive Power Resources

- Intact system and outage conditions
 - Maintain voltage criteria for
 - 90% maximum generator reactive power output
 - 90% minimum generator reactive power consumption

2017 Assessment – Capital Project Drivers

- Preliminary MTEP 17 Support Studies
- No Load Loss Contingency Needs – 3 years
- Multiple Outage Screening
- Generation - Transmission Studies
- Distribution - Transmission Studies
- Economic Benefits Studies
- Regional Reliability
- Public Policy Requirements, part of studies above
- Asset Renewal Studies

Preliminary MTEP17 Support Studies

- Initial screening (reduced generator reactive capability)
 - Summer peak (5 and 10 year models)
 - 2016 load forecast
 - 2016 TYA outside world (2015 MMWG cases)
- To support MTEP17 database development
 - No load loss allowed contingencies
 - Completed August 2016

No Load Loss Allowed Contingency Analysis

- **Peak**
 - 1, 5, and 10 year out models
- **Shoulder (firm)**
 - 5 and 10 year out models
 - 70% load except for Zone 2 (90% load) and northern Zone 4 (80% load)
 - Shoulder rating methodology
- **Minimum load**
 - 1 and 5 year out model
 - 40% load

Sensitivities

- Load Forecast – 90/10
- High W-E Bias Flows Scenario?
 - Future wind farms to the west in MISO DPP Cycle
 - Bias system to approximate potential wind locations?
 - ATC import level?
 - W-E bias level through ATC?
 - MUST or TARA type analysis?

Project List Updates – Before Next Annual

- Why?
 - Address changing needs quicker for new or changed projects
 - Keep 10-Year Assessment aligned with MTEP process
- Process
 - After annual update, before end of Q4 or Q1
 - New or revised Project Request (PR) is the trigger
 - AIM PR approval if needed
 - Manager PR and MTEP project approval
 - Collect until one month before quarter end
 - Present potential list to AIM
 - Post on 10-Year Assessment website
 - Send notice to stakeholders soliciting comments
 - Submit additions to MTEP before quarter end
- Types of Projects
 - Mostly D-T
 - Generally small projects
- When? Q4 2016?

Schedule

- Expected Load Forecast – October 2016
- Criteria and Methodology Update – November 2016
- Preliminary MTEP17 Support Study – Done
- Posted 2017 TYA Preliminary Study Design – November 2016
- Stakeholder Study Design Meeting – November 2, 2016
- Stakeholder Design Comments Due – December 1, 2016
- Study Design Completion – December 2016
- Model Development Completion – March 2017
- Preliminary Needs Meeting – February 2017
- Preliminary Solutions Meeting – April 2017
- Document and Publish – September 2017

Thank you for Participating

**To provide solicited comments or
for more information, please
contact**

Jeremy Voigt

Phone: 262-832-8742

Email: jvoigt@atcllc.com

By December 1, 2016

