

System Additions	Network Need Year	Projected In-Service Year	Planning Zone	Need Category	Planned, Proposed or Provisional	MTEP Appendix Status	MTEP Project ID
McMillan - Wildwood 115-kV line N-144 uprate	ASAP***	2018	1	Economics	Proposed	targeted A 17	13064
Plymouth Substation: Install 138 kV line breakers to sectionalize	2018***	2018	4	T-D Interconnection	Proposed	targeted A 17	13065
Tripp Rd Substation: Install 138 kV line breakers to sectionalize	2018***	2018	3	T-D Interconnection	Proposed	targeted A 17	13068
J390: Kittyhawk 345-kV Substation - loop line W-10 in and out	2019***	2019	3	G-T Interconnection	Proposed	targeted A 17	13103
Retap Colley Rd 138/69-kV T31 current transformers	2019***	2019	3	reliability (various TPL categories)	Proposed	targeted A 17	13003
Install a 4.98 Ohm series reactor on Paddock - NW Beloit line X-53	2019***	2019	3	reliability (various TPL categories)	Proposed	targeted A 17	13004
Juneautown Substation: Loop line 247K81 in and out	2020***	2020	5	T-D Interconnection	Proposed	targeted B 17	13104

Legend
* = dates based on approved project scope ISDs
** = SBRM Study Need Year
*** = Other Major Project Study need year
No Shading = No change to project since previous Assessment
Orange Shading = new project, was not in previous Assessment project list
Gray Shading = some change (e.g. In-service year or scope) since previous Assessment

There are no updates for the ATC Asset Renewal lists at this time.