



## **Generation Interconnections**

The size and location of new or expanded power plants can have significant impacts on the transmission system. These impacts can range from very positive (adding voltage support in a weak area of the system) to very negative (aggravating loading problems and/or causing generator instability). Information on the status, as of July 1, 2011, of ATC's portion of the Midwest Independent System Operator generation interconnection queue is provided in this section. There continues to be significant activity in ATC's portion of this queue, ranging from newly proposed generation projects to cancellation of previously proposed generation projects.

There are two key aspects in determining the total impacts a proposed new generator may have on the transmission system:

- impacts of interconnecting the new generator to the transmission system and
- impacts of using the transmission system to deliver power from the new generator.

Per the Midwest ISO Revised Attachment X process, a generator interconnection study is usually performed in three stages: Interconnection Feasibility Study (Application Review Phase), Interconnection System Impact Study (System Planning and Analysis and/or Definitive Planning Phase), and an Interconnection Facilities Study (Definitive Planning Phase)

The *Interconnection Feasibility Study* includes a determination of thermal overload or voltage level impacts created by the new generator. This study process is performed by MISO approximately five to six times per calendar year and provides a qualitative screen of the affected facilities, indicating if there is ample capacity on the system to support the new interconnection. Depending on the results of the study, the request may either enter into the Definitive Planning Phase (DPP), System Planning and Analysis Phase (SPA) or Customer Not Ready Phase of the System Impact study.

The *Interconnection System Impact Study* includes a determination of whether the proposed generator and other nearby generators will remain connected to the system under various disturbance situations, such as line trips and equipment failures and includes a fault duty analysis to determine whether existing system equipment can accommodate the increased short circuit fault duty caused by the new generator. Finally, the System Impact Study will identify solutions for any thermal, stability or fault duty deficiencies.

Delivery impacts are assessed during the DPP portion of the interconnection study process using the Midwest ISO deliverability methodology, which determines whether a new generator is deliverable to the Midwest ISO energy market and to what percent if not wholly deliverable. Whatever portion of the new generator that is deliverable may then be used as



a Network Resource by Network Customers through the Midwest ISO's Module E Resource Adequacy procedures.

The *Interconnection Facilities Study* is conducted in the DPP process phase to specify and estimate the time and cost of the equipment, engineering, procurement and construction of the system upgrades identified in the earlier interconnection studies.

The results of the interconnection studies are needed to develop a comprehensive picture of the transmission facilities that will be required for a proposed generator. These necessary changes to the transmission system are why we include in our Assessment models those proposed generators for which interconnection studies have been completed.

The first portion of this section provides the status of the generation queue within our service territory. The second portion of this section describes the transmission system additions associated with various proposed generation projects for which final interconnection studies have been completed. The third portion of this section describes some of the implications associated with interconnecting generation at various locations within our service territory.

### **ATC Generation Queue**

Since ATC's inception, eighteen new generators have gone into service and three up rates to existing generators have been completed, totaling approximately 5700 MW. These generators are shown in Table PR-26.

Table PR-27 lists the proposed generators in the generation queue for our service territory as of July 1, 2011. This table lists each proposed generation project and summarizes them by zone and MW amount. These proposed projects also are shown by approximate location in Figure PR-9. As shown, the total capacity of proposed generators in the queue is 2625.45 MW. Of that proposed capacity, wind units reflect 96 percent; nuclear up-rates reflect 2 percent and the remaining 2 percent is comprised of natural gas turbines (see Figure PR-10). Of this generation, 0 percent in Zone 1, 11 percent in Zone 2, 68 percent is proposed in Zone 3, 21 percent in Zone 4, and 0 percent in Zone 5. Table PR-29 lists the required network upgrades associated with the generators shown in Table PR-27 with a signed Interconnection Agreement.

The developer's projected in-service date listed in Table PR-27 is the last official commercial operation in-service date provided by the developer for that request. Under the Midwest ISO's former Attachment X procedures, a developer may suspend their Interconnection Agreement which may delay the project and were not required to update their official in-service date as part of this suspension.



The following request has been suspended:

- G590 – 98 MW wind farm, Line 971K91 in Calumet County, Wisconsin
- G611/G927 – 100.5 MW wind farm, Line 4035 in Calumet County, Wisconsin

Generation interconnection requests previously in the generation queue, which have been cancelled or removed from the queue since July 1, 2009 (because the developer withdrew the request or missed contractual milestones), are summarized in Table PR-28.

Link to publicly posted generation queue:

[http://oasis.midwestiso.org/documents/ATC/Cluster\\_8\\_Queue.html](http://oasis.midwestiso.org/documents/ATC/Cluster_8_Queue.html)

#### *Implications of generation development*

Availability of fuel, water and transmission interconnections are among the key aspects to be considered when sighting generation.

From a transmission perspective, the ability of the transmission system to accommodate new generation is a function of stability, power flow and short circuit analyses. For certain generation technologies, harmonics and voltage fluctuations may need to be considered as well. In most instances, new generation will require certain transmission system reinforcements to interconnect and deliver the generation output. In a few specific instances, new generation can be beneficial to the transmission system, perhaps even deferring or eliminating the need for transmission reinforcements that would be necessary absent the new generation. The ability of generation to defer or eliminate the need for transmission reinforcements also can be a function of the generation location, number of generators and/or expected generator capacity factor.

In this section, a general zone-by-zone evaluation of the likelihood of needing or deferring transmission reinforcements for various generator locations is provided. The purpose of these evaluations is to provide a cursory indication to the generation market of the likely magnitude of the impact and the transmission reinforcements that would likely be needed by general location.

#### **Zone 1**

Within Zone 1, generation has been proposed in various locations, and most of the proposals have involved generation located in the vicinity of the 345-kV infrastructure. Based on studies that we have conducted for proposed generation interconnections to date, some transmission reinforcements are likely to be required for any significant (>100 MW) generation development. The extent and nature of the reinforcements largely would be a function of where the power from the generation is to be delivered.

The reliability of the northern portion of Zone 1, the Rhinelander Loop, has been significantly improved with the completion of the new Cranberry to Conover 115 kV line and the Conover to Plains 138 kV conversion. While no new generator requests have been studied for this area, the addition of the Rhinelander Loop improvement projects may be able to support small-sized (up to 50 MW, depending on location) generation development, provided generator stability can be maintained, and provided it can be located in the northern portion of the Loop. Whether this generation would be cost-effective as a transmission-deferral mechanism would depend on a number of factors. The need for additional stability and thermal reinforcements in and outside of the Loop would be a function of where the new generation is sited and where the power is to be delivered. These improvements will be required to ensure that NERC reliability standards are continuously being met and that the security of the Rhinelander loop is not compromised.

The transmission infrastructure in the central portion of Zone 1 includes three new 345-kV lines which make up the GCMW corridor (Gardner Park – Highway 22, Morgan – Highway 22, and Highway 22 – Werner West). These additional lines significantly strengthen the Weston area, bringing much needed support to the area for both stability and thermal considerations for the new Weston 4 facility. A new generating facility was studied interconnecting 50 MW of biomass generation to the 115 kV transmission system located near the Weston substation. This study proved that properly sited generation of 50 MW or less can be accommodated to the transmission system in the area with minimal network upgrades. While the evaluation of new generation in this area is limited to this one study, it is possible that the GCMW corridor has the potential to support additional small to medium size generation development depending on actual physical location of the facility.

The infrastructure in the southern portion of Zone 1 consists of five 138-kV lines and several 69-kV lines. Only smaller generation projects (typically <25 MW) could be accommodated with minimal transmission reinforcements. The existing infrastructure in this portion of Zone 1 is not suitable for significant generation development.

The following table lists Zone 1 generator studies completed in the last five years.

*Zone 1 completed generation studies:*

| Request | Size     | Type               | County, State       | Status       |
|---------|----------|--------------------|---------------------|--------------|
| G588    | 55/60 MW | Combustion Turbine | Wood County, WI     | In-Service   |
| J040    | 50 MW    | Biomass            | Marathon County, WI | Out of Queue |

## Zone 2

We have completed studies of ten generation interconnection requests for the Zone 2 area. Even though the first six requests are no longer active in the queue, they have helped us build a base of knowledge similar to what we have in other zones relating to likely generation interconnection impacts.

ATC has seen substantial interest in siting wind turbine generators in the Upper Peninsula of Michigan. ATC has completed studying six wind farms located in Marquette, Houghton, Delta and Chippewa counties totaling 509 MW. One of the major challenges wind farms proposed for the Upper Peninsula will face is the limited transmission infrastructure to interconnect and deliver the energy produced by these power plants. Since the Upper Peninsula transmission grid was primarily designed to serve local load, substantial transmission upgrades area may be required to accommodate these proposed plants. The completion of the Northern Umbrella Plan, however, will result in a much more robust 138-kV network at Plains Substation that could accommodate medium sized generation in the future at or near Plains.

It is likely that given the scarcity of 138-kV infrastructure in the Upper Peninsula there are very few locations in Zone 2 that are ideal candidates for significant generation development. Generation studies have indicated substantial re-enforcements are required to accommodate small to medium size generation development throughout the Upper Peninsula.

There are areas in Zone 2, such as on the western end of the Upper Peninsula, which are or will be in need of transmission reinforcements where smaller generation projects could be beneficial in terms of deferring transmission expenditures. The allowable capacity of such generation would depend on the location. However, other potential impacts (stability, fault duties) would need to be evaluated on a location-by-location basis.

The following table lists Zone 2 generator studies completed in the last five years.

*Zone 2 completed generation studies:*

| Request  | Size          | Type    | County, State        | Status       |
|----------|---------------|---------|----------------------|--------------|
| G567-568 | 165 or 300 MW | Coal    | Delta County, MI     | Out of Queue |
| G583     | 19 MW         | Biomass | Ontonagon County, MI | Out of Queue |
| G750     | 201 MW        | Wind    | Marquette County, MI | Out of Queue |
| G799     | 120 MW        | Wind    | Houghton County, MI  | Out of Queue |
| G937     | 29 MW         | Wind    | Delta County, MI     | Out of Queue |
| J039     | 50 MW         | Biomass | Delta County, MI     | Out of Queue |



|      |       |         |                      |              |
|------|-------|---------|----------------------|--------------|
| J060 | 29 MW | Wind    | Delta County, MI     | In Queue     |
| J061 | 70 MW | Wind    | Delta County, MI     | In Queue     |
| J066 | 60 MW | Wind    | Chippewa County, MI  | In Queue     |
| J078 | 26 MW | Biomass | Marquette County, MI | Out of Queue |

## Zone 3

In Zone 3, generation has been proposed in various locations, but over half have been in the southern-most counties in Zone 3. Generation could be beneficial in a few areas depending on the capacity of such generation and the exact location.

Even with the on-going reinforcement plans for Dane County, smaller-scale generation (< 100 MW) in certain locations could be beneficial to improving the voltage profile in the area and potentially deferring transmission reinforcements. Stability analysis would need to be conducted to ensure stable operation of such generation.

Similarly, the southeast portion of Zone 3 is heavily loaded and will require transmission reinforcements in the future to ensure reliable operation. Small-scale generation in certain locations could be beneficial to changing power flow patterns and improving the voltage profile in the area. Generation studies completed in the southwest corner of the state have demonstrated that sighting large amounts of generation in rural areas may require substantial upgrades to the transmission system to ensure reliable operation.

The following table lists Zone 3 generator studies completed in the last five years.

*Zone 3 completed generation studies:*

| Request | Size   | Type         | County, State        | Status       |
|---------|--------|--------------|----------------------|--------------|
| G282    | 99 MW  | Wind         | Lafayette County, WI | In Queue     |
| G366    | 80 MW  | Wind         | Columbia County, WI  | Out of Queue |
| G527    | 280 MW | Coal         | Grant County, WI     | Out of Queue |
| G546    | 100 MW | Wind         | Walworth County, WI  | Out of Queue |
| G550    | 24 MW  | Simple cycle | Jefferson County, WI | In Service   |
| G553    | 280 MW | Coal         | Columbia County, WI  | Out of Queue |
| G706    | 99 MW  | Wind         | Columbia County, WI  | In Queue     |
| G724    | 99 MW  | Wind         | Dane County, WI      | Out of Queue |
| G747    | 99 MW  | Wind         | Rock County, WI      | Out of Queue |
| G749    | 50 MW  | Wind         | Lafayette County, WI | In Queue     |
| G793    | 100 MW | Wind         | Rock County, WI      | Out of Queue |
| G901    | 600 MW | Wind         | Winnebago County, IL | Out of Queue |

|      |         |      |                      |              |
|------|---------|------|----------------------|--------------|
| G902 | 600 MW  | Wind | Winnebago County, IL | Out of Queue |
| G953 | 49.5 MW | Wind | Grant County, WI     | Out of Queue |
| G954 | 49.5 MW | Wind | Grant County, WI     | Out of Queue |
| H012 | 150 MW  | Wind | Columbia County, WI  | In Queue     |
| H024 | 48 MW   | Wind | Columbia County, WI  | Out of Queue |
| J084 | 50 MW   | Wind | Grant County, WI     | In Queue     |

## Zone 4

Generation has been proposed in various locations in Zone 4. Generation could be beneficial in a few areas depending on the capacity of such generation and exact location. Given the nature of the issues in Zone 4, however, it is unlikely that new generation in Zone 4 will significantly alter the need for the major transmission reinforcements contemplated in that zone.

One area where generation could defer the need for transmission reinforcements is in Door County, provided such generation is small-scale (< 50 MW) and appropriately located. Currently, the northern portion of the county is served radially, and electric service is subject to interruption for the loss of the single 69-kV line serving the area. The voltage profile in Door County is projected to precipitate the need for reinforcements in the future. Small-scale generation potentially could defer certain of these reinforcements.

One area in Zone 4 that cannot accommodate any additional generation without significant transmission reinforcements is the area around the Point Beach and Kewaunee nuclear plants. In this area, existing transmission lines have little excess capacity and the existing generation requests have demonstrated that large scale transmission projects are needed for even modest increases in existing generation capacity. As the system evolves, stability margins at those plants may become a concern even with the transmission improvements. Siting of additional generation in the area will require extensive studies to ensure that system reliability will continue to be met for the existing generators in the area.

The following table lists Zone 4 generator studies completed in the last five years.

*Zone 4 completed generation studies:*

| Request | Size   | Type | County, State          | Status       |
|---------|--------|------|------------------------|--------------|
| G427    | 98 MW  | Wind | Fond du Lac County, WI | In Queue     |
| G507    | 68 MW  | Wind | Fond du Lac County, WI | In Service   |
| G590    | 98 MW  | Wind | Calumet County, WI     | In Queue     |
| G611    | 99 MW  | Wind | Calumet County, WI     | In Queue     |
| G773    | 150 MW | Wind | Brown County, WI       | Out of Queue |

|           |        |         |                      |              |
|-----------|--------|---------|----------------------|--------------|
| G833/J023 | 59 MW  | Nuclear | Manitowoc County, WI | In Service   |
| G834/J022 | 59 MW  | Nuclear | Manitowoc County, WI | In Queue     |
| G927      | 1.5 MW | Wind    | Calumet County, WI   | In Queue     |
| G987      | 400 MW | Wind    | Brown County, WI     | Out of Queue |
| J094      | 200 MW | Wind    | Manitowoc County, WI | In Queue     |

## Zone 5

Two major generation additions have been completed for Zone 5. The first addition is at Port Washington Power Plant, which was completed in June of 2008. In order to accommodate the two blocks of generation at Port Washington, the two Port Washington–Rangeline 138-kV lines and the three Port Washington–Saukville 138-kV lines were rebuilt in 2005 and the Saukville–Pleasant Valley–Arthur Road–St. Lawrence 138-kV line was rebuilt in 2007 at a cost of approximately \$10 million.

The other site for new generation is the Oak Creek Power Plant. The PSCW approved two new units at the Oak Creek Power Plant, with the first unit having gone into service in December of 2009 and the second unit achieving commercial service in January of 2011.

Studies of other proposed generation projects that are no longer in the generation queue indicate that additional generation in certain areas of Zone 5 would pose stability problems. In particular, larger-scale generation interconnecting to the 345-kV network could pose stability issues.

Smaller-scale generation in certain locations in Washington and Waukesha counties potentially could be accommodated without the need for transmission reinforcements if located appropriately.

The following table lists Zone 5 generator studies completed in the last five years.

*Zone 5 completed generation studies:*

| Request | Size    | Type       | County, State               | Status     |
|---------|---------|------------|-----------------------------|------------|
| G051    | 1300 MW | Coal/steam | Milwaukee County, Wisconsin | In Service |