

ATC's list of non-bulk electric system facilities (<100 kV) that will be operate to the ratings pre Study Based Ratings Methodology (SBRM) until they are reviewed and the SBRM is applied

	Transmission Line Names	Line Voltage
1	Plains - Bluff View SW STR 69kV	69
2	Bluff View SW STR - Bluff View 69kV	69
3	Aragon Tap - Norway 69kV	69
4	Aragon 6160 Tap - Aragon Tap 69kV	69
5	Aragon Tap - Aragon 69kV	69
6	Aragon 6160 Tap - Aragon 6150 Tap 69kV	69
7	Sagola Tap - Nordic 69kV	69
8	Sagola Tap - Sagola 69kV	69
9	Peavy Falls Hy - Sagola Tap 69kV	69
10	Cornell Tap (WEPCO) - Harris Tap 69kV	69
11	Nordic - Felch Mountain Tap 69kV	69
12	Sault SW STR - Sault 69kV	69
13	Sault SW STR - 3 Mile 69kV	69
14	3 Mile - 9 Mile SW STA 69kV	69
15	Nathan Tap - Nathan 69kV	69
16	Newberry Correctional Facility Tap - Newberry Correctional Facility 69kV	69
17	Hiawatha (ESE) - Engadine Tap 69kV	69
18	Engadine Tap - Newberry Tap 69kV	69
19	Engadine Tap - Engadine 69kV	69
20	Newberry Tap - Newberry 69kV	69
21	Newberry Tap - Newberry Correctional Facility Tap 69kV	69
22	Newberry Correctional Facility Tap - Roberts SW STA 69kV	69
23	Curtis Tap - Curtis 69kV	69
24	Blaney Park Sw Str - Curtis Tap 69kV	69
25	Gould City Sw Str - Hiawatha (ESE) 69kV	69
26	9 Mile SW STA - Pine River 69kV	69
27	Kincheloe Main Tap - Tone Tap 69kV	69
28	Tone Tap - Rudyard Tap 69kV	69
29	9 Mile SW STA - Kincheloe Main Tap 69kV	69
30	Rudyard Tap - Pine River 69kV	69
31	Kincheloe SW STA - Kincheloe Housing 69kV	69
32	Kincheloe SW STA - Kincheloe Main 69kV	69
33	Tone Tap - Tone 69kV	69
34	Rudyard Tap - Rudyard 69kV	69
35	Kincheloe Main Tap - Kincheloe SW STA 69kV	69
36	AGA Gas SW STR - AGA Gas 69kV	69
37	Pickford Tap - 6951 Tap (CLEC) 69kV	69
38	Goetzville Tap - Goetzville 69kV	69
39	9 Mile SW STA - Pickford Tap 69kV	69
40	6951 Tap (CLEC) - Goetzville Tap 69kV	69
41	Pickford Tap - Pickford 69kV	69
42	Goetzville Tap - Detour 69kV	69
43	Talentino Tap - Talentino SW STA 69kV	69
44	Talentino Tap - 6951 Tap (CLEC) 69kV	69
45	6951 Tap (ESE) - Talentino Tap 69kV	69
46	Lou Pac Tap - Lou Pac 69kV	69
47	Roberts SW STA - Lou Pac Tap 69kV	69
48	Lou Pac Tap - Newberry Vlg 69kV	69
49	Sycamore SW YD - East Towne 69kV	69
50	Sycamore SW YD - East Towne 69kV	69
51	Aspen - Michigamme Falls Hy 69kV	69
52	Pine Hy Tap - Pine Hy 69kV	69

ATC's list of non-bulk electric system facilities (<100 kV) that will be operate to the ratings pre Study Based Ratings Methodology (SBRM) until they are reviewed and the SBRM is applied

	Transmission Line Names	Line Voltage
53	Pine Hy Tap - Pine Hy 69kV	69
54	Aspen - Brule SW STA 69kV	69
55	Aspen - Peavy Falls Hy 69kV	69
56	Hiawatha Tap (AD-REA) - Hiawatha (AD-REA) 69kV	69
57	Manrap - Rapids 69kV	69
58	Brick Church - Lakehead Pipeline 69kV	69
59	Cornell Tap (UPPCO) - Watson Tap 69kV	69
60	Chandler - Cornell Tap (UPPCO) 69kV	69
61	Cornell Tap (UPPCO) - Cornell-UP 69kV	69
62	Watson Tap - Forsyth 69kV	69
63	Oak St - Lost Dauphin 69kV	69
64	Sunset Point - Bowen St 69kV	69
65	Bowen St - Oshkosh 69kV	69
66	Pioneer Tap (WPS) - Sobieski Sw Str 69kV	69
67	Portage St Hy - 3 Mile 69kV	69
68	3 Mile - 9 Mile SW STA 69kV	69
69	Pine Grove Tap - 9 Mile SW STA 69kV	69
70	Magazine - 3 Mile 69kV	69
71	Pine Grove Tap - Pine Grove 69kV	69
72	3 Mile - Pine Grove Tap 69kV	69
73	Rockview SW STR - 6951 Tap (ESE) 69kV	69
74	Rockview SW STR - Rockview 69kV	69
75	Pine River - Rockview SW STR 69kV	69
76	Limeston - Mich Limestone Loading Dock 69kV	69
77	6951 Tap (ESE) - Limeston 69kV	69
78	Straits - St Ignace 69kV	69
79	Trout Lake Tap (ESE) - Trout Lake (ESE) 69kV	69
80	Rexton Tap - Rexton 69kV	69
81	9 Mile SW STA - Dafter 69kV	69
82	Van Buren St - Henry St Tap (WPS) 69kV	69
83	Henry St Tap (WPS) - Finger Rd SW STA 69kV	69
84	Henry St Tap (WPS) - Henry St (WPS) 69kV	69
85	Ryan St - Glenview 69kV	69
86	Lost Dauphin - Ryan St 69kV	69
87	MTU Tap - MTU 69kV	69
88	Atlantic - MTU Tap 69kV	69
89	MTU Tap - Henry St. (UPPCO) 69kV	69
90	Industrial - Canal 69kV	69
91	Sawyer SW STA - Industrial 69kV	69
92	Iron Grove - Strawberry Hill Tap 69kV	69
93	Strawberry Hill Tap - Lakehead Iron River 69kV	69
94	Iron Grove - Strawberry Hill 69kV	69
95	Shingleton Tap - Shingleton 69kV	69
96	Timber Products Tap - Timber Products 69kV	69
97	Algoma SW STR - Algoma 69kV	69
98	Beardsley St - East Krok 69kV	69
99	Algoma SW STR - Algoma South 69kV	69
100	Barnett - Algoma SW STR 69kV	69
101	Algoma - Algoma City 69kV	69
102	Booster SW STR - Beardsley St 69kV	69
103	Algoma - Canal 69kV	69
104	Luxemburg 24.9 - Booster SW STR 69kV	69
105	Beardsley St - Barnett 69kV	69

ATC's list of non-bulk electric system facilities (<100 kV) that will be operate to the ratings pre Study Based Ratings Methodology (SBRM) until they are reviewed and the SBRM is applied

	Transmission Line Names	Line Voltage
106	Booster SW STR - Booster 69kV	69
107	Finger Rd SW STA - Luxemburg 24.9 69kV	69
108	Fox Hills SW STA - Silver Cliff 69kV	69
109	Fox Hills SW STA - Goodman 69kV	69
110	Caldron Falls Hy - Fox Hills SW STA 69kV	69
111	South Broadway Tap - Liberty St Tap 69kV	69
112	Henry St Tap (WPS) - Danz Ave SW STA 69kV	69
113	Finger Rd SW STA - Henry St Tap (WPS) 69kV	69
114	Glenview - Brillion Iron Works 69kV	69
115	Perch Lake - Mich Transmitter Facility 69kV	69
116	Darlington - DPC LaMont 69kV	69
117	Jennings Rd SW STA - DPC Argyle 69kV	69
118	DPC Shullsburg Tap - DPC Shullsburg 69kV	69
119	Shoto - Columbus (WPS) 69kV	69
120	Dorset Corners SW STR - DPC Oakdale 69kV	69
121	Dorset Corners SW STR - Dorset Corners 69kV	69
122	DPC Kendall - Dorset Corners SW STR 69kV	69
123	Hillsboro - DPC Kendall 69kV	69
124	Council Creek - DPC Oakdale 69kV	69
125	Council Creek - DPC Monroe County 69kV	69
126	Humboldt Sw Str - Greenstone 69kV	69
127	North Lake - Humboldt Sw Str 69kV	69
128	Humboldt Sw Str - Humboldt Mine 69kV	69
129	North Lake - Barnum 69kV	69
130	New Holstein SW STA - St Nazianz 69kV	69
131	St Nazianz - Custer 69kV	69
132	Portage (UPPCO) - Atlantic 69kV	69
133	Ellinwood - Oshkosh 69kV	69
134	High Falls Hy - Caldron Falls Hy 69kV	69
135	Centennial Mine Tap - Keweenaw 69kV	69
136	Osceola - Centennial Mine Tap 69kV	69
137	K I Sawyer Tap - K I Sawyer 69kV	69
138	K I Sawyer Tap - Sawyer Lumber 69kV	69
139	Amberg - Daves Falls 69kV	69
140	Suamico - Sobieski Sw Str 69kV	69
141	Pulliam SW YD - Suamico 69kV	69
142	Sobieski Sw Str - Sobieski 69kV	69
143	Wells St Tap - Ogden St 69kV	69
144	Baraga VLG Tap - L'anse 69kV	69
145	L'anse - JH Warden 69kV	69
146	Baraga VLG Tap - Baraga Vlg 69kV	69
147	DPC Lyndon STA SW STR - DPC Lyndon Station 69kV	69
148	Katzenberg - Richmond Rd SW STR 69kV	69
149	Richmond Rd SW STR - Twin Lakes (ALTE) 69kV	69
150	Sunset Point - Winneconne 69kV	69
151	Hampden SW STR - Hampden 69kV	69
152	Sigel - Vesper Tap 69kV	69
153	Vesper Tap - Vesper 69kV	69
154	Vesper Tap - Pittsville 69kV	69
155	Darlington - Rock Branch 69kV	69
156	Columbus (ALTE) - Columbus Muni 1 69kV	69
157	Gays Mills SW STR - Gays Mills 69kV	69
158	Seneca SW STR - Seneca 69kV	69

ATC's list of non-bulk electric system facilities (<100 kV) that will be operate to the ratings pre Study Based Ratings Methodology (SBRM) until they are reviewed and the SBRM is applied

	Transmission Line Names	Line Voltage
159	Lancaster - Lancaster Distribution 69kV	69
160	Hickory St Tap 2 - Macy St Tap 69kV	69
161	North Fond Du Lac - Hickory St 69kV	69
162	Morris St North Tap 2 - Mercury Marine 69kV	69
163	Hillside - Brisbois 69kV	69
164	Oregon - Brooklyn 69kV	69
165	DPC Ocean Spray SW STR - DPC Ocean Spray 69kV	69
166	CWEC Scandinavia Tap - CWEC Scandinavia 69kV	69
167	Amherst Jct SW STR - Amherst Jct 69kV	69
168	Polar SW STR - Polar 69kV	69
169	Centennial Park SW STR - Centennial Park 69kV	69
170	Waunakee Ind Park SW STR - Waunakee Industrial Park 69kV	69
171	Division Street SW STR - Division Street 69kV	69
172	Juneau Muni SW STR - Juneau Northside Tap 69kV	69
173	Juneau Northside Tap - Juneau Downtown Tap 69kV	69
174	Juneau Downtown Tap - Juneau Industrial Tap 1 69kV	69
175	Juneau Industrial Tap 1 - Juneau Industrial 69kV	69
176	Juneau Northside Tap - Juneau Northside 69kV	69
177	Juneau Downtown Tap - Juneau Downtown 69kV	69
178	Token Creek Tap - Token Creek 69kV	69
179	Deforest - Token Creek Tap 69kV	69
180	Bird St Tap - Bird St 69kV	69
181	Bird St Tap - Sun Prairie 69kV	69
182	Ninth Street Tap - Ninth Street 69kV	69
183	Ninth Street Tap - Spruce Street 69kV	69
184	Milwaukee Valve Tap - Milwaukee Valve 69kV	69
185	Dam Heights - Dam Heights South Tap 69kV	69
186	Cross Plains - Stage Coach SW STA 69kV	69
187	Easy Street SW STR - Easy Street 69kV	69
188	Grand Marsh Tap - ACEC Brooks 69kV	69
189	Grand Marsh Tap - Grand Marsh 69kV	69
190	ACEC Brooks SW STR - Grand Marsh Tap 69kV	69
191	Lincoln Pump STA - ACEC Brooks SW STR 69kV	69
192	ACEC Brooks SW STR - Mckenna 69kV	69
193	East Rockton SW STR - East Rockton 69kV	69
194	Browntown - Jennings Rd SW STA 69kV	69
195	South Monroe - Browntown 69kV	69
196	Ripon - Ripon 2 SW STR 69kV	69
197	Ripon 2 SW STR - Ripon Ind Park 69kV	69
198	Merrimac SW STR - Merrimac 69kV	69
199	Caledonia SW STR - Caledonia (ALTE) 69kV	69
200	Eagle View Sw Str - Eagle View 69kV	69
201	Finnegan Tap - Finnegan 69kV	69
202	Finnegan Tap - Platt 69kV	69
203	Hubbard - Spring Brook 69kV	69
204	Montello Sw Str - ACEC Turtle Lake SW STR 69kV	69
205	ACEC Turtle Lake SW STR - Wautoma 69kV	69
206	ACEC Turtle Lake SW STR - ACEC Turtle Lake 69kV	69
207	Mount Horeb - East Lincoln St 69kV	69
208	ACEC Coloma Tap - Chaffee Creek 69kV	69
209	ACEC Coloma Tap - ACEC Coloma 69kV	69
210	Lincoln Pump STA - ACEC Coloma Tap 69kV	69
211	ACEC Wildrose SW STR - ACEC Wildrose 69kV	69

ATC's list of non-bulk electric system facilities (<100 kV) that will be operate to the ratings pre Study Based Ratings Methodology (SBRM) until they are reviewed and the SBRM is applied

	Transmission Line Names	Line Voltage
212	ACEC Wild Rose Pump SW STR - ACEC Wild Rose Pump 69kV	69
213	ACEC Wautoma SW STR - ACEC Wautoma 69kV	69
214	ACEC Doylestown SW STR - ACEC Doylestown 69kV	69
215	Fall River SW STR - Fall River 69kV	69
216	Union Center SW STR 2 - Wonewoc 69kV	69
217	Union Center SW STR 1 - Union Center SW STR 2 69kV	69
218	Union Center SW STR 2 - Union Center 69kV	69
219	Hillsboro Tap - Hillsboro 69kV	69
220	Dorset Corners SW STR - Dorset Corners 69kV	69
221	Kieler Tap - Kieler 69kV	69
222	DPC Dayton - Eagle Tap 69kV	69
223	Burke Tap - Burke 69kV	69
224	Columbus Muni #3 Tap - Maple Street 69kV	69
225	Alto SW STR - Alto 69kV	69
226	Mackford Prairie SW STR - Mackford Prairie 69kV	69
227	Markesan SW STR - Markesan 69kV	69
228	Mackford Prairie SW STR - Ripon 69kV	69
229	Markesan SW STR - Mackford Prairie SW STR 69kV	69
230	North Fond Du Lac - Sadoff Co Tap 69kV	69
231	Macy St Tap - Macy St 69kV	69
232	Sadoff Co Tap - Macy St Tap 69kV	69
233	Saratoga - ACEC Grant 69kV	69
234	Saratoga - ACEC Arrowhead SW STR 69kV	69
235	ACEC Cottonville Tap - ACEC Sherwood 69kV	69
236	ACEC Cottonville Tap - ACEC Cottonville 69kV	69
237	ACEC Arrowhead SW STR - ACEC Arrowhead 69kV	69
238	ACEC Arrowhead SW STR - ACEC Cottonville Tap 69kV	69
239	Monroe St Sw Str - Adams St Sw Str 1 69kV	69
240	Monroe St Sw Str - Monroe St 69kV	69
241	Bemis SW STR - Bemis 69kV	69
242	Reedsburg - Reedsburg Main 69kV	69
243	Reedsburg #6 Industrial Park - Artesian 69kV	69
244	Waupun Prison Tap - Waupun Prison 69kV	69
245	Com Tech Sw Str - Waupun Tap 69kV	69
246	Waupun Prison Tap - Waupun Southside SW STR 69kV	69
247	Waupun Westside SW STR - Waupun Prison Tap 69kV	69
248	Waupun Southside SW STR - Waupun Southside 69kV	69
249	Com Tech Sw Str - Com Tech 69kV	69
250	Waupun - Waupun Main 69kV	69
251	Waupun Southside SW STR - Com Tech Sw Str 69kV	69
252	North Mullet River - Plymouth Sub 2 69kV	69
253	32nd St Sw Str - 32nd St 69kV	69
254	Nicolet SW STR - 32nd St Sw Str 69kV	69
255	Scot Forge Tap 2 - Scot Forge 1 69kV	69
256	REC Clinton SW STR - REC Clinton 69kV	69
257	Scot Forge Tap 1 - Clinton (ALTE) 69kV	69
258	Scot Forge Tap 1 - Scot Forge Tap 2 69kV	69
259	Clinton SW STR (ALTE) - Scot Forge Tap 1 69kV	69
260	Sharon SW STR - Sharon 69kV	69
261	Enzyme Bio-Systems SW STR - Enzyme Bio-Systems 69kV	69
262	Spring Grove SW STR - Brodhead SW STA 69kV	69
263	Rock Branch - Dodgeville 69kV	69
264	Dodgeville - Hooterville 69kV	69

ATC's list of non-bulk electric system facilities (<100 kV) that will be operate to the ratings pre Study Based Ratings Methodology (SBRM) until they are reviewed and the SBRM is applied

Transmission Line Names		Line Voltage
265	Janesville General SW YD - Badger Pump STA Tap 69kV	69
266	Badger Pump STA Tap - Badger Pump STA 69kV	69
267	Badger Pump STA Tap - Parker High School SW STR 69kV	69
268	Castle Rock - DPC Buckhorn SW STR 69kV	69
269	DPC Buckhorn SW STR - DPC Buckhorn 69kV	69
270	DPC Buckhorn SW STR - Hilltop (ALTE) 69kV	69
271	Belleville - Verona 69kV	69
272	New Glarus SW STR - New Glarus 69kV	69
273	Monticello SW STR - Monticello (ALTE) 69kV	69
274	New Glarus SW STR - Belleville 69kV	69
275	Caroline - Marion SW STR 69kV	69
276	CWEC Tigerton Tap - CWEC Tigerton 69kV	69
277	Marion SW STR - Marion 69kV	69
278	CWEC Tigerton Tap - Whitcomb 69kV	69
279	Marion SW STR - CWEC Tigerton Tap 69kV	69
280	Rudolph SW STR - Rudolph 69kV	69
281	Northern Steel Casting SW STR - Northern Steel Casting 69kV	69
282	ACEC Quincy Tap - ACEC Quincy 69kV	69
283	ACEC Richford SW STR - ACEC Richford 69kV	69
284	North Mullet River - Plymouth Muni 3 Tap 69kV	69

ATC's list of non-bulk electric system facilities (<100 kV) that will be operate to the ratings pre Study Based Ratings Methodology (SBRM) until they are reviewed and the SBRM is applied

	Transmission Line Names	Line Voltage
285	Northside (ALTE) Tap - Northside (sfm) (ALTE) 69kV	69
286	Plymouth Muni 3 Tap - Plymouth Sub 3 69kV	69
287	Zenda SW STR - Zenda 69kV	69
288	Artesian - Reedsburg 69kV	69
289	Reedsburg - Loganville 69kV	69
290	Northwest Beloit Tap - Northwest Beloit 69kV	69
291	Shirland Ave SW STR - Shirland Ave 69kV	69
292	Manawa SW STR - Harrison North 138kV 69kV	69
293	CWEC Iola Tap - CWEC Iola 69kV	69
294	Iola - CWEC Iola Tap 69kV	69
295	Manawa SW STR - Manawa 69kV	69
296	Beaver Dam 3rd St South SW STR - Beaver Dam 3rd St 69kV	69
297	Center St SW STR - Center St 69kV	69
298	Beaver Dam 3rd St North SW STR - Beaver Dam 3rd St 69kV	69
299	Mercury Marine Tap - Mercury Marine 69kV	69
300	Willow Lawn Tap - Willow Lawn 69kV	69
301	South Fond Du Lac SW YD - Willow Lawn Tap 69kV	69
302	Morris St North Tap 1 - Morris St 69kV	69
303	Morris St South Tap 1 - Morris St 69kV	69
304	Dana Corp SW STR - Dana Corp 69kV	69
305	DPC Platteville Tap - Pioneer(ALTE) 69kV	69
306	DPC Platteville Tap - DPC Platteville 69kV	69
307	Hillman - DPC Platteville Tap 69kV	69
308	Sheridan (ALTE) Sw Str - Harrison 69kV SW STR 69kV	69
309	Iola - Sheridan (ALTE) Sw Str 69kV	69
310	CWEC Rosholt Tap - Rosholt CWEC 69kV	69
311	Rosholt CWEC - Groenier 69kV	69
312	CWEC Rosholt Tap - Rosholt 69kV	69
313	Rosholt SW STR - CWEC Rosholt Tap 69kV	69
314	Colt Industrial SW STR - Colt Industries 69kV	69
315	Cranston SW STR - Cranston 69kV	69
316	REC Newark SW STR - REC Newark 69kV	69
317	DPC New Lisbon Tap - DPC New Lisbon 69kV	69
318	West Mauston Tap - Hilltop (ALTE) 69kV	69
319	Council Creek - Camp Douglas Tap 69kV	69
320	DPC New Lisbon Tap - West Mauston Tap 69kV	69
321	Camp Douglas Tap - DPC New Lisbon Tap 69kV	69
322	Camp Douglas Tap - Camp Douglas 69kV	69
323	Dam Heights North Tap - Dam Heights South Tap 69kV	69
324	Island Tap - Island 69kV	69
325	Island Tap - Kirkwood 69kV	69
326	Badger Ordinance Works Tap - Badger Ordinance Works 69kV	69
327	Badger Ordinance Works Tap - Baraboo 69kV	69
328	Moore St Tap - Island Tap 69kV	69
329	Dam Heights - Dam Heights North Tap 69kV	69
330	Moore St Tap - Moore St 69kV	69
331	Dam Heights North Tap - Badger Ordinance Works Tap 69kV	69
332	Baraboo - Moore St Tap 69kV	69
333	Ripon 1 Tap - Ripon 2 SW STR 69kV	69
334	High Falls Hy - Mountain 69kV	69
335	Milton Lawns Tap - Milton Lawns 69kV	69
336	Cottage Grove SW STR - Cottage Grove 69kV	69
337	Orfordville SW STR - Orfordville 69kV	69

ATC's list of non-bulk electric system facilities (<100 kV) that will be operate to the ratings pre Study Based Ratings Methodology (SBRM) until they are reviewed and the SBRM is applied

Transmission Line Names		Line Voltage
338	Brodhead Muni 1 SW STR - Brodhead North 69kV	69
339	Orfordville SW STR - Bass Creek 69kV	69
340	Brodhead Muni 1 SW STR - REC Orfordville SW STR 69kV	69
341	Brodhead Muni 2 SW STR - Brodhead Tap 69kV	69
342	Brodhead Muni 3 SW STR - Brodhead Muni 2 SW STR 69kV	69
343	Brodhead Muni 2 SW STR - Brodhead Central 69kV	69
344	Brodhead Muni 3 SW STR - Brodhead South 69kV	69
345	Brodhead Tap - Brodhead 69kV	69
346	REC Orfordville SW STR - REC Orfordville 69kV	69
347	Brodhead SW STA - Brodhead Muni 3 SW STR 69kV	69
348	REC Orfordville SW STR - Orfordville SW STR 69kV	69
349	Brodhead Tap - Brodhead Muni 1 SW STR 69kV	69
350	Boscobel - Boscobel Muni 69kV	69
351	West Mauston Tap 2 - Mauston Tap 69kV	69
352	West Mauston Tap 2 - West Mauston Tap 69kV	69
353	West Mauston - West Mauston Tap 2 69kV	69
354	Mauston Tap - Mauston 69kV	69
355	Hillman - Mcgregor (ALTE) 69kV	69
356	Metomen - Brandon Tap 69kV	69
357	Berlin - Fox River 69kV	69
358	Port Edwards - Georgia Pacific 69kV	69
359	Canal - Sawyer SW STA 69kV	69
360	Nicolet Paper Co - Oak St 69kV	69
361	Highway V - Nicolet Paper Co 69kV	69