

Table ZS-3
2021 Limitations and Performance Criteria Exceeded

Planning Zone	Criteria Exceeded/Need	2021 Summer Peak Case		2021 Minimum Load Case		2021 70% Shoulder Case		2021 90% E-W Bias Case		2021 65% High W-E Bias Case		Facility Outage(s)
		% of Facility Rating	% of Nominal Bus Voltage	% of Facility Rating	% of Nominal Bus Voltage	% of Facility Rating	% of Nominal Bus Voltage	% of Facility Rating	% of Nominal Bus Voltage	% of Facility Rating	% of Nominal Bus Voltage	
1	Base case loading criteria exceeded	TRUE	--	FALSE	--	FALSE	--	FALSE	--	TRUE	--	System Intact
1	Base case voltage criteria exceeded	--	FALSE	--	TRUE	--	FALSE	--	FALSE	--	FALSE	System Intact
1	Dartford, Ripon Industrial Park, Northwest Ripon and Ripon 69-kV buses	--	90.5 - 91.9% 90.6 - 91.9% 91.6%	--	--	--	--	--	--	--	--	Ripon - NW Ripon Tap 69-kV line Metomen - Ripon 69-kV line NW Ripon Tap - Dartford Tap 69-kV line
1	Winneconne, Omro and Omro Industrial Park 69-kV buses	--	90.8 - 91.4%	--	--	--	--	--	--	--	--	Winneconne - Sunset Point 69-kV line
1	Council Creek 161-kV bus	--	91.2%	--	--	--	--	--	--	--	--	Monroe County - La Crosse 161-kV line
1	Council Creek 138-kV bus	--	--	--	105.5%	--	--	--	--	--	--	System Intact
1	Metomen 138/69 KV transformer	95.6%	--	--	--	--	--	--	--	--	--	System Intact
1	Petenwell 138/69 KV transformer	101.7% 106.2% 104.1% 103.5% 101.4 - 103.3%	--	--	--	95.6 - 104.2%	--	--	--	119.2%	--	System Intact Castle Rock - Quincy ACEC 69-kV line Hilltop - Buckhorn Tap 69-kV line Castle Rock - McKenna 69-kV line ¹⁴ Plus other less severe contingencies
1	Castle Rock - ACEC Quincy 69-kV line	98.8% 98.8% 98.7%	--	--	--	--	--	--	--	--	--	Petenwell - Big Pond 69-kV line Petenwell 138/69-kV Transformer Necedah Tap - Big Pond 69-kV line
1	ACEC Badger West - Petenwell 138-kV line	--	--	--	--	96.9 - 135.9%	--	--	--	96.1 - 103.8%	--	Arpin - Eau Claire 345-kV line King - Eau Claire 345-kV line Arpin 345/138-kV transformer Arrowhead - Stone Lake 345-kV line Plus other less severe contingencies
1	ACEC Badger West - Saratoga 138-kV line	--	--	--	--	97.1 - 132.7%	--	--	--	100.5%	--	Arpin - Eau Claire 345-kV line King - Eau Claire 345-kV line Arpin 345/138-kV transformer Arrowhead - Stone Lake 345-kV line Plus other less severe contingencies
2	Base case loading criteria exceeded	FALSE	--	FALSE	--	FALSE	--	FALSE	--	FALSE	--	System Intact
2	Base case voltage criteria exceeded	--	FALSE	--	FALSE	--	FALSE	--	FALSE	--	FALSE	System Intact
2	Engadine, Newberry, Newberry Hospital, Roberts, LouPac, Newberry Village, Hulbert, Eckerman 69-kV buses	--	84.4-90.4% --	--	--	--	--	--	88.5-89.0% 89.5-89.8%			Hiawatha-Engadine 69-kV line Engadine-Newberry 69-kV line
3	Base case loading criteria exceeded	FALSE	--	FALSE	--	FALSE	--	FALSE	--	FALSE	--	System Intact
3	Base case voltage criteria exceeded	--	FALSE	--	FALSE	--	FALSE	--	FALSE	--	FALSE	System Intact
3	Darlington – North Monroe 138-kV line	--	--	--	--	--	--	--	--	118.8 – 98.8%	--	Paddock 345/138-kV transformer Darlington 138/69-kV transformer Darlington – DPC Gratiot 69-kV line Eden – Wyoming Valley 138-kV line Eden – Wyoming Valley – Spring Green 138-kV line plus other less severe contingencies
3	Eden – Mineral Point 69-kV line	--	--	--	--	--	--	--	--	111.3 – 98.5%	--	Darlington – Lafayette Wind 138-kV line
3	South Monroe – Browntown – Jennings Road – Wiate 69-kV line	--	--	--	--	--	--	--	--	110.8 – 101.2%	--	Darlington – North Monroe 138-kV line
3	Nelson Dewey 161/138-kV transformer	--	--	--	--	96.0%	--	--	--	--	--	System Intact
3	Nelson Dewey 161/138-kV transformer	--	--	--	--	103.1 – 99.4%	--	--	--	--	--	Nelson Dewey Unit 2 Pleasant Praire Unit 1 Pleasant Praire Unit 2 Edgewater Unit 5 plus other less severe contingencies
3	Royster – Sycamore 69-kV line	106.3%	--	--	--	--	--	96.3%	--	--	--	Femrite 138/69-kV transformer

Table ZS-3
2021 Limitations and Performance Criteria Exceeded

Planning Zone	Criteria Exceeded/Need	2021 Summer Peak Case		2021 Minimum Load Case		2021 70% Shoulder Case		2021 90% E-W Bias Case		2021 65% High W-E Bias Case		Facility Outage(s)
		% of Facility Rating	% of Nominal Bus Voltage	% of Facility Rating	% of Nominal Bus Voltage	% of Facility Rating	% of Nominal Bus Voltage	% of Facility Rating	% of Nominal Bus Voltage	% of Facility Rating	% of Nominal Bus Voltage	
3	Westport – Wanakee Muni#2 69-kV line	98.1%	--	--	--	--	--	--	--	--	--	West Middleton – Pheasant Branch 69-kV line
3	Verona 138-kV bus	--	87.9%	--	--	--	90.8%	--	88.8%	--	91.4%	Verona – Oak Ridge 138-kV line Verona 138/69-kV transformer
3	Huiskamp 138-kV bus	--	89.4%	--	114.8%	--	90.1%	--	90.4%	--	91.4%	Huiskamp – North Madison 138-kV line
3	Hubbard and Hustisford 138-kV bus	--	87.5% 88.1% 88.1%	--	87.5% 87.6% 87.6%	--	86.9% 87.3% 87.3%	--	88.1% 88.1% 88.1%	--	87.2% 87.2% 87.1%	Rubicon – Hustisford 138-kV line Hustisford – Hubbard 138-kV line Rubicon – Hustisford – Hubbard 138-kV line
3	Paddock – Townline 138kV line	--	--	--	--	102.8% 101.8% 101.1%	--	--	--	--	--	NW Neloit – Paddock 138-kV line Paddock – NW Beloit – Blackhawk 138-kV line NW Beloit – Blackhawk 138-kV line
3	NW Beloit – Paddock 138kV line	--	--	--	--	96.9%	--	--	--	--	--	Paddock – Townline 138-kV line
4	Base case loading criteria exceeded	FALSE	--	FALSE	--	TRUE	--	FALSE	--	FALSE	--	System Intact
4	Base case voltage criteria exceeded	--	FALSE	--	--	--	--	--	--	--	--	System Intact
4	Manrap – Custer 69-kV line	99.3%	--	--	--	--	--	--	--	--	--	Dewey – Lakefront 69-kV line
4	Glenview – Gravesville 69-kV line	103.7% 103.7% 103.7% 97.0% 97.0%	--	--	--	--	--	--	--	--	--	Tecumseh Road 138/69 kV Transformer* Tecumseh Road 138/69 kV Transformer Tecumseh Road - Ford Drive tap 69-kV line Ford Drive tap - New Holstein 69-kV line Tecumseh Road - New Holstein 69-kV line*
4	Sunset Point – Pearl Avenue 69-kV line	110.5% 110.4%	--	--	--	--	--	98.9% 98.9%	--	--	--	Ellinwood 138/69-kV transformer* Ellinwood – 12th Avenue 69-kV line
4	Morgan – Falls 138-kV line	--	--	--	--	101.8%	--	--	--	--	--	Morgan – Plains 345-kV line
4	Elkhart Lake – Saukville 138-kV line	--	--	--	--	--	--	--	--	97.9%	--	Barnhart – Cedarsauk 345-kV line
4	Kewaunee 138-kV bus	--	--	--	103.6%	--	--	--	--	--	--	System Intact
5	Base case loading criteria exceeded	FALSE	--	FALSE	--	FALSE	--	FALSE	--	FALSE	--	System Intact
5	Base case voltage criteria exceeded	--	FALSE	--	TRUE	--	FALSE	--	FALSE	--	FALSE	System Intact
5	Oak Creek 345/230-kV transformer T895	104.3% 102.5%	--	--	--	--	--	104.4% 102.5%	--	102.7% 99.8%	--	Split Oak Creek 230-kV bus 78 Split Oak Creek 230-kV bus 67
5	Bain 345/138-kV transformer #5	158.4% 104.6%	--	--	--	--	--	--	--	--	--	Split Pleasant Prairie 345-kV bus 34 Split Pleasant Prairie 345-kV bus 23
5	Arcadian4 – Waukesha1 138-kV line	98.4%	--	--	--	110.2%	--	120.4%	--	--	--	Arcadian6 – Waukesha3 138-kV line
5	Arcadian6 – Waukesha3 138-kV line	95.3%	--	--	--	106.8% 95.8%	--	116.6% 102.0%	--	--	--	Arcadian4 – Waukesha1 138-kV line Split Waukesha 1-2 bus
5	Arcadian 345/138-kV transformer #3	--	--	--	--	--	--	95.9%	--	--	--	Arcadian 345/138-kV transformer #1
5	Pleasant Prairie – Zion 345-kV line	--	--	--	--	--	--	--	--	108.2% 101.1% 98.8%	--	Zion – Arcadian 345-kV line Zion - Arcadian 345-kV line ¹⁴ System Intact
5	Lakeview – Zion 138-kV line Arcadian – Zion 345-kV line Kenosha - Lakeview 138-kV line	96.8% -- 99.6%	--	--	--	--	--	--	--	144% 108.1% 141.9%	--	Pleasant Prairie – Zion 345-kV line
5	Bain – Kenosha 138-kV line	--	--	--	--	--	--	--	--	107.8%	--	Pleasant Prairie – Zion 345-kV line
5	Albers – Kenosha 138-kV line	--	--	--	--	100.4%	--	--	--	--	--	Albers – Bain 138-kV line
5	Maple and Germantown 138-kV buses	--	--	--	--	--	--	--	89.7-90.3%	--	--	Saukville – Maple 138-kV line