



## Zone 2 - 2026 study results

Refer to [Table ZS-4](#) and [Figure ZS-8](#)

### *Summary of key findings*

- Limitations identified will be addressed in projects outlined in the [2012](#) and [2016](#) sections.

There are three thermal limitations and several voltage limitations listed in [Table ZS-4](#). The voltage and thermal limitations occur in the Munising/Newberry, eastern U.P. and Escanaba areas and will be mitigated by projects described in the [2012](#) and [2016](#) study results.

Please refer to the [ATC Energy Collaborative – Michigan](#) for further information.

### *Projects whose “Need date” precedes the “In-service date”*

- None

### *Projects whose “In-service date” precedes the “Need date”*

- None

### **Assessment of Steady State Compliance with NERC Standards**

The mitigation plans comprised of planned, proposed and provisional projects identified for Zone 2 in this Assessment will allow the ATC system in Zone 2 to meet the steady state portions of NERC standards TPL-001 and TPL-002 in each of the five years 2012-2016, and for the 2017-2021 planning horizon.