



Helping to keep the lights on,  
businesses running  
and communities strong®

# 2019 10-Year Assessment Preliminary Needs

Stakeholder and Customer Presentation  
February 28, 2019  
Curtis Roe & Scott Adams

# Purpose

- Solicit Input on Needs
  - Network Planning
    - Assumptions Review
    - Needs: Limitations
  - Asset Renewal
- Solicit Input on Public Policy Driven Needs
- Summarize Next Steps


# Assumptions Review

- Studies
- Load Forecast
- Generation/Imports/Flows

# Core Assessment Studies

2018 TYA		2019 TYA	
<i>Model</i>	<i>Years Studied</i>	<i>Model</i>	<i>Years Studied</i>
Summer Peak	2019, 2023, 2028	Summer Peak	2020, 2024, 2029
Shoulder	2023, 2028	Shoulder	2024, 2029
40% Minimum Load	2019, 2023	40% Minimum Load	2020, 2024

# Load Forecast Trends



Forecast Year	10-Year Average Growth Rate
2018	0.50%
2017	0.53%
2016	0.52%
2015	0.66%
2014	0.68%

# Load Forecast Trends, Continued

Model	ATC Load (MW)		
	2017 Assessment	2018 Assessment	2019 Assessment
Year 1 Summer Peak	13,070	13,010	12,610
Year 5 Summer Peak	+320	+440	+160
Year 10 Summer Peak	+640	+660	+340
Year 5 Shoulder	9,530	9,360	9,050
Year 10 Shoulder	+230	+160	+120

# Off-Peak Load Forecasts

- **Shoulder**
  - 70% of summer peak in Zones 1, 3, southern 4, and 5
  - 80% of summer peak in northern Zone 4
  - 90% of summer peak in Zone 2
- **Minimum**
  - 40% of summer peak for all Zones
  - Power factors: historical minimum for a Local Balancing Authority

# Generation Dispatch Changes Compared to the 2018 Assessment

- **Retirements**
  - Lakefront D2: 5.1 MW
- **Additions**
  - J557: 0.9 MW solar farm at Garden City
- **Changes**
  - J711: 135 MW wind farm at new Silver River Substation GIA  
Withdrawn since 2018 TYA
  - Mackinac HVDC setting changed from 20 to 5 MW from North to South



# Generation Dispatch Changes Compared to the 2018 Assessment, Continued

- ATC Net Interchange

Model	ATC Net Interchange		
	2018 Assessment	2019 Assessment	Difference
Year 1 Summer Peak	-88	-60	28
Year 5 Summer Peak	-129	-52	77
Year 10 Summer Peak	-363	-51	312
Year 5 Shoulder	-259	-209	50
Year 10 Shoulder	-258	-209	49

# Flow Changes Compared to 2018 Assessment

- **Potential Causes**

- Interchange variation
- Variation in dispatching generation outside of ATC

Model	ATC Western Interface Flow		ATC Southern Interface Flow	
	2018 Assessment	2019 Assessment	2018 Assessment	2019 Assessment
Year 1 Summer Peak	-700	-795	595	732
Year 5 Summer Peak	-399	-617	252	562
Year 10 Summer Peak	-677	-414	297	359
Year 5 Shoulder	-767	-861	488	649
Year 10 Shoulder	-406	-605	131	394

# Needs: Limitations

Model	Planning Zone	Monitored Facility	Category	Possible Mitigation
2020 Peak	3	Portage B2 to Columbia 138-kV line	P12 & P32	Transitional Ratings
2020 Peak	3	Portage to Columbia 138-kV line	P12 & P32	Transitional Ratings
2024 Peak	3	Portage B2 to Columbia 138-kV line	P12 & P32	Portage - Columbia 138-kV line rebuild X-13
2024 Peak	3	Portage to Columbia 138-kV line	P12 & P32	Portage - Columbia 138-kV line rebuild X-20
2029 Peak	3	Portage B2 to Columbia 138-kV line	P12 & P32	Portage - Columbia 138-kV line rebuild X-13
2029 Peak	3	Portage to Columbia 138-kV line	P12 & P32	Portage - Columbia 138-kV line rebuild X-20
2029 Peak	4	Lost Dauphin to Red Maple 138-kV line	P32	HVDC Adjustment 10 South to North
2029 Peak	4	Point Beach to Kewaunee 345-kV line	P32	Fox Generation Redispatch

# Needs: Near Miss

Model	Planning Zone	Monitored Facility	Category	Possible Mitigation
2029 Peak	3	Bass Creek to Town Line Road 138-kV line	P11	Emergency Rating not Exceeded
2020 Peak	3	Columbia 138/69-kV Transformer	P13 & P33	Columbia: Replace Breaker
2029 Peak	3	Columbia 345/138 kV-transformer	P23	Columbia: Replace Breaker
2024 Peak	3	Sheepskin to Stoughton 69-kV line	P32	Emergency Rating not Exceeded
2029 Peak	3	Stage Coach to West Middleton 69-kV line	P13	West Middleton - Stagecoach 69 kV line rebuild 6927
2029 Peak	3	Timberlane Tap to West Middleton 69-kV line	P32 & P33	West Middleton - Stagecoach 69 kV line rebuild 6927
2029 Peak	4	Fox to North Appleton 345-kV line	P32	Emergency Rating not Exceeded
2024 Peak	4	Glory Road to De Pere 138-kV line	P11	Emergency Rating not Exceeded
2029 Peak	4	Glory Road to De Pere 138-kV line	P11	Emergency Rating not Exceeded
2024 Peak	4	Lost Dauphin to Red Maple 138-kV line	P32	Emergency Rating not Exceeded
2029 Peak	4	Lost Dauphin to Red Maple 138-kV line	P32	Emergency Rating not Exceeded
2024 Peak	4	Point Beach to Kewaunee 345-kV line	P32	Emergency Rating not Exceeded
2029 Peak	4	Point Beach to Kewaunee 345-kV line	P32	Emergency Rating not Exceeded

# Asset Renewal Program Objectives

- Safety – public and worker
- Minimize total life cycle cost (NPV from customer cost/rate perspective)
- Compliance
- Manage risk
- Reliability performance improvements
- Environmental performance improvements
- Coordination with Stakeholders

# Asset Renewal Program Criteria

## •Condition

- O&M Cost savings
- Health indexing
- Performance and projected deterioration

## •Obsolescence

- Manufacturer and Field technical support
- Spare parts availability
- Application
- Analog phone circuit elimination

## •Reliability

- Industry failure rates
- Known design issues
- Single element failure and testing exposure
- Outage reduction
- Poor lightning performance
- Relay system misoperations, security, dependability
- Human performance issues

- Compliance,
- Safety,
- Environmental

- Ratings methodology (FAC-008)
- NESC clearance from grade and other structures
- NESC working clearances in control houses
- NESC structure strength
- Environmental impacts
- Operational risk

# Customer Cost versus Reliability

Reliability

Cost


Time



# Reliability Performance: January - December 2018


## Customer Impact

TSAIDI




The 9.19 minute T-SAIDI YTD has exceeded our YE five year average of 6.59 minutes.

TSAIFI



The 0.065 T-SAIFI YTD has exceeded our YE five year average of 0.055.

## Total Forced Outages



### 2018 Top impacting outages:


January 3: Albers SS - Failed Substation Equipment (18,885 customers, 1.37 min. T-SAIDI).

April 14 & 15 Ice Storm: 36 circuit outages (26,862 customers, 0.010 T-SAIFI).

August 28: EF-2 Tornado: 23 structures down (11,330 customers, 1.89 min. T-SAIDI) and failed distribution communication antenna (6,771 customers, 0.83 min. T-SAIDI).

Sept. 21: Conductor damage from live off ROW tree fall in on radial circuit accounted for 1.09 minutes of T-SAIDI.

## Total Circuit Outages by Cause Code





# Coordinated Asset Renewal Process

- **Objective: Optimize efficiency and reduce project costs**
  - Collaborate on schedules, priorities and work load leveling
  - Provide internal coordination between Planning, Operations, Maintenance, Construction, Engineering and Asset Management
  - Stakeholder input through ATC Customer Relations
  - Track Program ISD and specific Project Deferrals
  - Provide a 10 year forecast for internal and external stakeholders




# Asset Renewal – Preliminary 10 Year Forecast Equipment Quantity

**Asset Renewal Equipment Quantities Forecast by Asset Type - 2023-2032**

Row Labels	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	Grand Total
Arresters	54	8	18		9		9			3	101
Batteries and Chargers	17	28	20	22	12	24	16	14	13	12	178
Breakers and Switchers	44	21	26	5	27	8	36	19	5	9	200
Capacitor Banks			2	1	2	3	5	7	2	3	25
Control Houses	2	2	5	2		3	5	4	1	3	27
Instrument Transformers	22	43	17	18	61	47	109	50	28	79	474
Power Transformers	11	10	9	4	7	8	5	4	1	5	64
Reactors		3	2			3	1				9
Relays	210	105	180	295	284	245	440	333	169	291	2552
SCADA	21	22	16	29	39	29	40	32	30	54	312
Switches	150	65	72	67	70	33	68	48	14	70	657
<b>Grand Total</b>	<b>531</b>	<b>307</b>	<b>367</b>	<b>443</b>	<b>511</b>	<b>403</b>	<b>734</b>	<b>511</b>	<b>263</b>	<b>529</b>	<b>4599</b>

# Asset Management Renewal Plans - T-Line

- Objective is to manage condition and preserve reliability and safety as these assets reach end of life.
- Pre-1970 vintage wood poles will need replacement in the next 20 years.



# Asset Management Renewal Plans - T-Line

- Over next twenty years ATC will need to build approximately 100 miles per year.

Voltage Class	Mono Wood Poles	Multi - Wood Pole Structures*	Number of Wood Poles on Multi-Wood Pole Structures	Grand Total Number of Wood Poles	Grand Total Number of Wood Structures	Average Span Length (ft.)	Number of Miles per Year Next 20 Year
69	14374	703	1532	15906	15077	300	43
115	3	1182	2434	2437	1185	650	7
138	991	5047	10533	11524	6038	650	37
345		1532	3152	3152	1532	950	14
<b>Grand Total</b>	<b>15368</b>	<b>8464</b>	<b>17651</b>	<b>33019</b>	<b>23832</b>		<b>101</b>

\* Multi - Wood Pole Structure is comprised of two (H-Frame) or more wood pole structures



Continuing Asset Renewal Condition Need	Projected Need Year	Project Status	Planning Zone	MISO MTEP Appendix Status	MTEP PRjID	MTEP Cost (M\$)
North Lake – Greenstone 69kV line (NLKY11) Rebuild	2023	Provisional	2	--	--	10-25
Portage - 9 Mile 69kV lines (6901/ESE_6902) Re-insulate	2023	Provisional	2	--	--	<10
Gwinn- KI Sawyer 69kV line (Sawyer) Re-insulate	2023	Provisional	2	--	--	<10
Chandler-Delta (UPPCO) 69kV line (Delta 1) Partial Rebuild	2023	Provisional	2	--	--	<10
Academy - Columbus 69kV line (Y21) Rebuild	2023	Provisional	3	B	10590	<10
Danz Ave – University (WPS) 69-kV line (O-15) Underground Transmission Section	2023	Provisional	4	Target A, MTEP19	15924	10-25
South Beaver Dam - Horicon 69kV line (Y134) Rebuild	2026	Provisional	3	--	--	10-25
Conover-Mass 69kV line (6530) Partial Rebuild	2025	Provisional	2	Target B, MTEP19	16495	<10
9 Mile SW STA - Pine River 69kV lines (6921/23) Partial Rebuild	2025	Provisional	2	Target B, MTEP19	16496	<10
Blaney Park SW STA – Mich. Limestone Quarry Tap 69kV line (6914) Partial Rebuild	2025	Provisional	2	--	--	<10
Replace East Krok 138/69 kV T1 Transformer	2025	Provisional	4	--	--	<10
University-Whitewater 138kV line (UNIG51) Rebuild	2027	Provisional	5	--	--	10-25
University - Mukwonago 138kV line (UNIG52) Rebuild	2027	Provisional	5	--	--	>25
Darlington – Rock Branch 69kV line (Y109) Rebuild	2026	Provisional	3	--	--	10-25
Retire Lone Rock 69-kV Phase Shifter	2026	Provisional	3	--	--	<10

# Public Policy Requirements – Comments?

- Any public policy driven needs that may not be covered by the Assessment process?

# Assessment Status

- **Next Steps**

- Needs comments – due March 22
- Finalize needs – end of March
- Preliminary solutions meeting/presentation – May 2
- Finish sensitivity studies – May
- Develop new or revised scope and cost estimates – June
- Complete multiple outage study – June
- Draft study write-up – July
- ATC internal review/approval – August
- 2019 Assessment publication – September



# Questions?

Curtis Roe

Phone: (262) 506-6775

Email: [croe@atcllc.com](mailto:croe@atcllc.com)

Scott Adams

Phone: (906) 779-7930

Email: [sadams@atcllc.com](mailto:sadams@atcllc.com)

