



Helping to keep the lights on,  
businesses running  
and communities strong®

## 2019 10-Year Assessment Preliminary Study Design

October 25, 2018  
Stakeholder and Customer Webcast  
Jeremy Voigt, System Planning


# Purpose

- Summarize ATC's project development processes
- Solicit input for the 2019 Assessment Study Design
- Solicit input on Public Policy Requirements


# ATC's Project Development Processes

- Local Transmission Planning
  - Asset Renewal
  - Interconnections
  - Network
    - Planning Reliability Criteria
    - Sectionalizing Guidelines
    - Economic Benefits Considerations
- Other Solution Considerations (non-transmission alternatives)
- Regional Planning
- Public Policy Requirements

# Timeline



# ATC Project Identification Process



# ATC Project Status Definitions

← Development → Implementation →

**Strategic**

**Provisional**

**Proposed**

**Planned**

**In-Service**



# Asset Renewal Program Objectives


- Safety – Public and worker
- Minimize total life cycle cost
- Compliance
- Manage risk of aging infrastructure
- Reliability performance improvements
- Environmental performance improvements

# Asset Renewal Criteria

## Safety/Compliance



## Reliability Performance






# Asset Renewal Considerations

- Is the asset still needed?
  - Assess area needs
  - Obtain cross-functional and distribution provider input
  - Consider removal of lines (full/partial retirement)
- What ratings are needed?
- Investing prudently using defensible criteria

# Asset Renewal Considerations – E-83/B-2 (Past Example)

- ATC team and affected distribution provider assessed area needs
- Found potential for full or partial retirement
  - Preferred alternative: move substations nearby existing 138 kV lines
  - Existing 69 kV lines fully retired




# Interconnections

- **G-T**
  - Support MISO Attachment X and Y Processes
- **D-T**
  - Collaboration with distribution providers through Load Interconnection Request Form (LIRF) and BVP process
- **T-T**
  - Collaboration with other Transmission Owners

# Network Planning Objectives

- Compliance with NERC regional and local criteria
- Best Value Plan (BVP)
- Customer involvement
- Address Public Policy requirements
- Maintain or improve the adequacy and reliability of the electric transmission system

# Network Planning Assessment Process



# Planning Criteria & Assessment Practices

- NERC Standards, particularly [TPL-001, version 4](#)
- ATC Planning Criteria/Assessment Practices
  - <http://www.atc10yearplan.com> (About tab)
  - Updates to Planning Criteria v19.1 & Planning Assessment Practices v7
- Sectionalizing Guidelines
  - Developed with distribution providers early in ATC's history
  - <http://www.atcllc.com/wp-content/uploads/2017/12/Load-Interconnection-Guide-Rev-7-121517-Pub.pdf> (Sections 3.6.1-3.6.2)

# Planning Criteria & Assessment Practices Updates

- **Planning Criteria v19.1**

- Added a footnote in Section 1.1 to clarify how ATC addresses appropriate ratings for loading and voltage limitations
- Added ATC's interpretation of NERC Cascading in Section 1.1.2

- **Planning Assessment Practices v7**

- Modified sections 13.1 Types of Analysis and 13.2 Compliance with Applicable Requirements
- Now include depending on some MISO MTEP analysis

# 2019 Studies and Assumptions

- Preliminary 2018 Load Forecast Confirmation and MTEP19 Support Studies
- Modeling Assumptions
  - Model Years
  - Load
  - Generation
  - No Load Loss Allowed Contingency Analysis
- Additional Studies



# Preliminary Load Forecast and MTEP19 Support Studies

- Initial screening (reduced generator reactive capability)
  - Summer peak (5 and 10 year models)
  - 2018 load forecast
  - 2018 TYA outside world (2017 MMWG cases)
- To confirm 2018 Load Forecast and support MTEP19 database development
  - No load loss allowed contingencies
  - Completed July 2018

# Projects Submitted to MTEP19

- [MTEP19 Active Project List](#)

# 2019 TYA Model Years

- 2019 (As-planned)
  - 2020
  - 2024
  - 2029
- All models will likely be completed by the Spring of 2019


# Load - Historical

- Requested September 28, 2018
  - Summer peak
  - Winter peak
  - Light load
  - Shoulder load
- Receive November 1, 2018
- Add to databases

# Load – Expected Forecast

- Requested LDC forecasts February 2018
  - 11 years
  - Consistent with resource planning forecast
  - Considered expected (50/50 probability)
- Received in Quarter 2 of 2018
- ATC compiles
  - Comparisons to previous forecasts
  - Differences confirmed with LDCs
  - Finalized copy to LDCs – August 2018
  - Forecasts used to plan the system

# Load Forecast Trends



| Forecast Year | 10-Year Average Growth Rate |
|---------------|-----------------------------|
| 2018          | 0.50%                       |
| 2017          | 0.53%                       |
| 2016          | 0.52%                       |
| 2015          | 0.66%                       |
| 2014          | 0.68%                       |



## Load Forecast Trends, Continued

| Model                  | ATC Load (MW)      |                    |                    |
|------------------------|--------------------|--------------------|--------------------|
|                        | 2017<br>Assessment | 2018<br>Assessment | 2019<br>Assessment |
| Year 1<br>Summer Peak  | 13,000             | 13,000             | 12,300             |
| Year 5<br>Summer Peak  | +300               | +400               | +400               |
| Year 10<br>Summer Peak | +600               | +600               | +600               |
|                        |                    |                    |                    |
| Year 5 Shoulder        | 9,400              | 9,400              | 8,900              |
| Year 10 Shoulder       | +200               | +100               | +100               |

# Generation Modeling

- **Existing generator data**
  - Annual updates requested from GOs in Q3 of each year
- **Generation additions**
  - Only add generators with signed interconnection agreements
  - Additions modeled at MISO Facility study location
- **Generation retirements**
  - Generators with a completed MISO Attachment Y are modeled as retired, unless there is an SSR agreement
- **Intact system and outage conditions**
  - Maintain voltage criteria for
    - 90% maximum generator reactive power output
    - 90% minimum generator reactive power consumption



# Generation Dispatch

- **Local Balancing Area merit order dispatch:**
  - Used for Assessment summer peak and shoulder models. Local Balancing Area dispatch from merit order provided by LBA
- **ATC-wide merit order dispatch:**
  - Minimum load models
  - ATC-wide merit order dispatch determined with PROMOD
- **Generators without scheduled transactions:**
  - If signed IA, generation included in the host Local Balancing Area.

# No Load Loss Allowed Contingency Analysis

- **Peak**
  - 1, 5, and 10 year out models
- **Shoulder (firm)**
  - 5 and 10 year out models
  - 70% load except for Zone 2 (90% load) and northern Zone 4 (80% load)
  - Shoulder rating methodology
- **Minimum load**
  - 1 and 5 year out model
  - 40% load, may be adjusted based on analysis of historical loads

# Additional Network Planning Studies

- Load Loss Allowed
- Existing Generator Stability Reviews
- Annual Fault Study
- Proposed – Next Limiting Element Study
  - Identify next few limiters
  - Just informational
- Proposed – Load Loss Allowed Manual Mitigation (2-year study)
- Proposed – Getting back to Rate A (2-year study)

# Non-transmission Alternative Considerations

- Preliminary process developing with our stakeholders
- Two ways process can be initiated
  - Need initiated by local distribution provider
    - Identify T or D related reliability/service concerns
    - Develop needs and solutions
    - Communicate with ATC to promote collaboration
      - Use existing D-T or G-T processes
  - Need initiated by ATC
    - 10-Year Assessment screening – develop Needs/Limitations lists
    - Customers/stakeholders engage ATC with ideas
    - Collaborate to identify possible DER options from customers
    - Open project development discussions
    - Use modified BVP practices to balance comparison of appropriate alternatives

# Network Limitations Potential NTA Information Example

| Model       | Planning Zone | Monitored Facility  | Category |
|-------------|---------------|---|----------|
| (Year) Peak | 1,2,3,4,5     | Substation1 – Substation2 69, 115, 138, 230, 345 kV (Name) Line | P1#, P3# |

| % of Facility Rating | % of Nominal Bus Voltage | Normal Rating (MVA) | Emergency Rating (MVA) | Possible Mitigation | MTEP PRjID | MTEP Cost or Cost Range (\$) |
|----------------------|--------------------------|---------------------|------------------------|---------------------|------------|------------------------------|
| ##%                  | ##%                      | ##                  | ##                     | Project1            | ####       | ## or ##-##                  |

# Asset Renewal Needs Potential NTA Information Example

| Continuing Asset Renewal Condition Need  | 2018 Projected Need Year | 2019 Projected Need Year | Project Status                 |
|--|--------------------------|--------------------------|--------------------------------|
| Substation1 – Substation2 69, 115, 138, 230, 345 kV line (Name) Partial Rebuild or Rebuild | ####                     | ####                     | Provisional, Proposed, Planned |

| Planning Zone | Need Category       | MISO MTEP19 Appendix Status | MTEP PRjID | MTEP Cost or Cost Range (M\$) | Length (Miles) | Connected Load (MW) | Network Type    |
|---------------|---------------------|-----------------------------|------------|-------------------------------|----------------|---------------------|-----------------|
| 1,2,3,4,5     | Description of need | A, B, --                    | ####       | ## or ##-##                   | TBD/##         | ##-##               | Network, Radial |

# Regional Planning

- **MTEP**
  - Preliminary screening helps ATC to better prepare for upcoming MTEP cycle
- **MISO Coordinated Seasonal Assessments**
- **RF Seasonal Assessments**

# Public Policy Requirements

- Following MISO Tariff (Attachment FF) Processes
- Previously identified requirements
  - State Renewable Portfolio Standard (RPS) mandates
  - EPA regulations
  - State mandates and goals for energy efficiency (EE) and demand side management (DSM) programs
- Any public policy requirements not identified in ATC or MISO processes?



# Schedule

- Expected Load Forecast – Review complete August 16, 2018
- Criteria and Methodology Review – Comments by November 30, 2018
- Preliminary MTEP19 Support Study – Done
- Post 2019 TYA Preliminary Study Design – Done
- Stakeholder Study Design Meeting – October 25, 2018
- Stakeholder Design Comments Due – November 30, 2018
- Study Design Completion – December 2018
- Model Development Completion – March 2019
- Preliminary Needs Meeting – February 28, 2019
- Preliminary Solutions Meeting – May 2, 2019
- Document and Publish – September 2019

Thank you for Participating

**To provide solicited comments or  
for more information, please  
contact**

Jeremy Voigt

Phone: 262-832-8742

Email: [jvoigt@atcllc.com](mailto:jvoigt@atcllc.com)

By November 30, 2018

