

2023 10-Year Assessment Preliminary Needs

Stakeholder and Customer Webcast

PRESENTED BY

Ted Weber, Matt Waldron, Scott Adams, Matt Falkowski, Kerry Marinan, Michael Billups, Amy Wilke, Anna Torgerson, Logan Brecklin

March 6, 2023




Purpose – Ted Weber

- Define and Solicit Input on Needs
 - Network/System Planning
 - Generation Interconnection/Generation to Transmission (G-T) and Distribution to Transmission (D-T)
 - Asset Renewal
 - Communications
- Solicit Input on Public Policy Driven Needs
- Summarize Next Steps

Preliminary Needs


- We are seeing new projects based on new needs this year.
 - New network reliability projects
 - Additional renewable interconnections & generation retirements
 - Distributed Energy Resources (DERs)
 - Madison-area substation asset renewal work
 - Changes in regulatory body priorities & policies

Rocky Run T2 and T4 Replacement




- N-1-1 Limitations on T2 and T4 at Rocky Run
 - Scope to replace both T2 and T4 with a single larger 345/115kV 500 MVA unit
- Target MTEP23 App A
- ISD of 6/1/2026

East Krok T1 Replacement




- N-1-1 contingencies causing thermal limitations
 - Scope: Replace existing transformer with new 138/69kV 100 MVA
- Future asset renewal needs
- Real-time constraints may require radializing Door Co
- MTEP23 App A

Mullet River Area Reliability




- Multiple N-1-1 contingencies causing thermal and voltage limitations
 - Existing mitigation radializes load
- Asset renewal needs and space constraints at existing sites
- MTEP22 App B

Eden-Rock Branch (Y-106) – Anna Torgerson



- Historical Congestion
 - N-1 Generation Curtailment
- Structure Replacements needed based on condition and performance
- OPGW Communications
- ISD 2026 - 2028

Colburn Load Interconnection Request



- Load Interconnection Request
 - Colburn area load growth
- Additional Source Need
 - Limited Y-302 substation load bridging capabilities in summer/winter months
- Evaluating networked service to Colburn/Y-302
- Target Appendix B, MTEP23

Distribution to Transmission (D-T) Interconnections

100 requests in 2022


- Governing documents:
 - FERC Tariff Attachment FF-ATCLLC
 - NERC Standards
 - FERC Filed D-T Interconnection Agreement (IA)
 - ATC's Load Interconnection Guide
 - ATC's Business Practices

D-T Best Value Planning (BVP) Process


- Collaborative planning assessment to determine the best value solution for all parties
- Types of requests
 - New distribution substation
 - Distribution substation equipment change
 - Distributed energy resources (DERs)
 - Unforecasted load or change in load characteristics
 - Power quality issues
- Individual Project Timelines Vary Widely

D-T Dashboard

193 Active Projects



D-T Interconnection Requests by Year Including Distributed Energy Resources (DER)




MISO Generation Interconnections Process

- FERC approved GIP timeline reduction in 2022
- Decreases time from 505 calendar days to 373 days
- Starting with 2022 MISO Queue

Generator Interconnection Process


DPP Phase 1 + DPP Phase 2 + DPP Phase 3 + GIA = ~ 373 Days



Refer to full GI Process Flow Diagram and notes for more detail: [GI Application and DPP Readiness](#)



G-T Project Dashboard



Active MISO GT Projects

136

Developers

43

Total MWs in Queue

18.41K

- Solar - 10.4 GW
- Storage - 4.8 GW
- Gas - 1.8 GW
- Wind - 1.4 GW

ATC's Asset Renewal strategy is about balancing Performance Risk and Life Cycle Costs – Scott Adams



Asset Renewal Program Objectives


- Safety – public and worker
- Minimize total life cycle cost [Net Present Value of Revenue Requirements (NPV RR) from customer cost/rate perspective]
- Compliance
- Manage risk
- Reliable performance – maintain or improvement
- Environmental performance improvements
- Coordination with Stakeholders

Replacement is based on...


(Hint: Not Age!)

- **Safety** – public and worker
- **Condition** – tests, maintenance costs/risks
- **Obsolescence** – part availability, factory support, craft labor expertise with this specific equipment, available spares
- **Utilization** – application, system changes
- **Criticality** – consequence of failure, outage impacts
- **Costs** – maintenance and replacement
- **Environmental** – PCB contamination, oil volumes and containment, proximity to waterways, SF6 gas leaks, lead, mercury, environmental compliance/risks
- **Compliance** – NERC, CIP, EPA, State DNR
- **Other Considerations** – test frequency, on-line monitoring, test information available, fleet size, common fleet issues, maintenance history, failure mode, industry experience

Reliability Trend – Annual Forced Outages




2010 - 2022 Fair Weather/Storm Outage Comparison



Reliability Performance: January - December 2022

Customer Impact



The 6.82 T-SAIDI YTD is 0.80 minutes less than our five year average of 7.62 minutes.



The 0.055 T-SAIFI YTD is 0.010 less than our five year average of 0.065.

Total Forced Outages



The 307 total Forced Outages YTD are 23 less than our five year average of 330.


2022 Top impacting outages:

June 15th - Severe storms impacted 27,816 customers (20 delivery points). This event accounted for 1.38 of the 6.82 minutes (20%) of T-SAIDI and 0.010 of the 0.055 (18%) of T-SAIFI YTD.


July 8th - An Unknown outage on D-82 impacted 23,578 customers (7 delivery points). This event accounted for 0.009 (16%) of the 0.055 T-SAIFI YTD. Circuit K-37 storm repairs caused the unusual configuration.

July 23rd - High winds on July 23rd took down 15 poles on circuits Y80 and Y103 impacting 6,260 customers (3 delivery points) for 20.5 hours. This accounted for 2.89 of the 6.82 minutes (42%) of T-SAIDI YTD.

Total Circuit Outages by Cause Code



Circuit Breakers Age Distribution




EquipmentSubType	Age <10	Age 11-20	Age 21-30	Age 31-40	Age 41-50	Age 51-60	Age >60
SF6GasBreakers	711	932	397	94	8		
OilBreakers			2	59	112	85	
VacuumBreakers				1			
Total	711	932	399	154	120	85	

Number of Breakers in Fleet

786 69 kV
1378 115/138/161 kV
232 230/345 kV
2401 Total


SF6 Equipment Leakage Tracking 2007-2022

SF6 Maintenance Gas Additions by Year




2021 Year End SF₆ Nameplate Capacity ≈ 220,489 pounds
2012 – Edgewater GIS bus leak = 1376#

PCB Reduction Plan



500 gallon per year reduction estimated beyond 2020


Presque Isle Switchyard – Breaker Asset Renewal



- 15 oil circuit breakers to be replaced, consider configuration
- Hydraulic Operating Mechanism is high maintenance and prone to leaks
- parts are no longer manufactured and limited field support
- HV bushings are at end of reliable life


Overhead Transmission Lines – Wood Pole Lines 20-year Outlook

- Objective is to manage condition and preserve reliability and safety as these assets reach end of life.
- Pre-1980 vintage wood poles are likely to be replaced in the next 20 - 25 years.



Overhead Transmission Lines – Steel Lattice Lines – Preliminary 20-year Outlook

- Objective is to manage condition and preserve reliability and safety as these pre-1940's assets reach end of life.
- Pre-1940 vintage lattice tower structures are likely to be replaced in the next 20 - 25 years.



Asset Renewal T-line Needs Example


- Portage – Dam Heights 69kV Rebuild (Line Y-16)
 - Project Background
 - ◆ Approximately 25 of miles of rebuild
 - Past Needs
 - ◆ Condition and Performance Issues
 - ◆ Replace 1910's vintage lattice structures
 - ◆ Outages: One of the most frequently outage ATC lines
 - ✓ On average about 4 outages per year
 - ✓ Need to update to avian friendly design
 - ✓ Improved lightning performance
 - Current status
 - ◆ Project went in-service Fall of 2017
 - ◆ One lightning outage since the new design went into service (Design 45kA strike, actual 192kA strike)



Communications Reliability Program (CRP) Projects - 2023 & Beyond

- Challenges, Trends & Opportunities
 - Telecom Carrier Performance & Service Challenges
 - Future Substation Communication Demands
 - T-Line Asset Management & System Planning Alignment

Communication Reliability Program (CRP) Projects - In Service Fiber and Active CRP Projects



Label:	CRP - MTEP ²³ Projects:	PCO Cost Estimate
1	OPGW - Line 5066 - (St Martins to Bluemound)	\$6,113,441.00
2	OPGW - Line I-9 - (Pine to Skanawan Tap Structure: #107651)	\$7,499,000.00
3	OPGW - Line Y-62 - (Wick Drive to Black Earth)	\$4,096,584.00
4	OPGW - Line Y-159 - (Walworth to Brick Church)	\$3,104,796.00
5	OPGW - Line NWHG41 - (Barland to Norwich)	\$1,599,709.00
Total Estimate:		\$22,413,530.00
Label:	CRP - MTEP ²⁴ Projects:	PCO Cost Estimate
6	OPGW - Line HOLLG21 (Holland to Structure: #9662)	\$4,014,313.00
7	OPGW - Line X-118 - (Freeman to Presque Isle)	\$3,823,107.00
8	OPGW - Line B-102 - (Rapids to Revere Dr) OPGW - Line Y-MRP11 - (Manrap to Custer)	\$2,745,930.00
9	UG Fiber - (Dewey to Russell Term) UG Fiber - (Montana to Norwich) UG Fiber - (Center - Fiebrantz)	\$6,433,466.00
Total Estimate:		\$17,016,816.00

Ambient Adjusted Ratings (AAR) - Anna Torgerson

Existing 4-line Pilot Program

Working on:

- AAR calculation methodology
- Equipment Prioritization
- EMS Modeling
- Verification

Assessment Status – Ted Weber

- Next Steps

- Needs comments – due March 26
- Finalize needs – Early April
- Preliminary solutions meeting/presentation – May 9
- Finish sensitivity studies – May
- Develop new or revised scope and cost estimates – June
- ATC internal review/approval – August
- 2023 Assessment publication – November

Contacts

Allison Bartz (TYA) and Ted Weber (TYA)

Email: abartz@atcllc.com and tweber2@atcllc.com

Matt Waldron (G-T and D-T)

Email: mwaldron@atcllc.com

Scott Adams (Asset Management Substation) or Justin Nettesheim (AR T-line)

Email: sadams@atcllc.com or jnettesheim@atcllc.com

Matt Falkowski (Communications)

Email: mfalkowski@atcllc.com

Any additional questions?