

# 2024 10-Year Assessment Preliminary Needs

*Stakeholder and Customer Webcast*

**PRESENTED BY:**

System Planning, ATC

March 11, 2024

- ATC Proprietary -

[atcllc.com](http://atcllc.com)

# Purpose

- Define and Solicit Input on Needs
  - Network/System Planning
  - Generation Interconnection/Generation to Transmission (G-T) and Distribution to Transmission (D-T)
  - Asset Renewal
  - Communications
- Solicit Input on Public Policy Driven Needs
- Summarize Next Steps

# Preliminary Needs


- We are seeing new projects based on new needs this year.
  - New network reliability projects
  - Additional renewable interconnections & generation retirements
  - Distributed Energy Resources (DERs)
  - Substation and T-line asset renewal work
  - Changes in regulatory body priorities & policies

# 7 Mile Creek – Saratoga, new 138 kV line




- Multiple system conditions causing congestions.
- Add a 138kV line between Saratoga and 7 Mile Creek by rebuilding a portion of Y-301 as double circuit 138 kV / 69 kV
- MTEP24, Target App A

# Sun Prairie Area Reliability Project



- N-1-1 contingencies causing thermal limitations
  - Y-81 Loop-In-Loop-Out configuration in Reiner Road SS
  - Y-137 Loop-In-Loop-Out configuration in Yahara River SS
  - Sun Prairie SS, Jumper Replacements
  - Other Asset Renewal needs
- Target Appendix B, MTEP24

# Mullet River Area Reliability Project



- Multiple N-1-1 contingencies causing thermal and voltage limitations
  - Existing mitigation radializes load
- Asset renewal needs and space constraints at existing sites
- Target Appendix A, MTEP24

# Y-77 High Falls – Mountain 69 kV Rebuild



- Long radial connection that traverses through Nicolet National Forest
- 1960's vintage wood pole structures are in lower condition, OPGW for backup communications and future flexibility.
- Rebuild line and install OPGW approximately 16.5 miles from High Falls to Mountain Substation
- Appendix A, MTEP23


# Y-74 Hilltop-Council Creek 69kV Rebuild



- 1960's single circuit wood pole line that is in lower condition. Other benefit of connecting fiber into ATC larger fiber network.
- rebuild and install OPGW on approximately 29.5 miles
  - Coordination of work at Camp Douglas and New Lisbon
- Target Appendix B, MTEP24




# Presque Isle Asset Renewal Project



- Oil Circuit Breakers part of program for removal, relays and switches at equipment end of useful life.
- Reconfigure station equipment, install new breakers, relays, and switches.
- Target Appendix B, MTEP24

# Racine County, DIC, New Substation



- New load interconnection request in the SE Wisconsin
- ISD targeting Q2 2025
- Project scope:
  - New 138/24.9 kV Interconnection Nimbus Substation
  - Two short 138 kV double-circuit transmission lines (<1.0 miles)
  - Expansion of the Mt. Pleasant Substation
  - New FACTS device at Mt. Pleasant
  - Scope may be expanded to support the future buildout of the EITM zone
- ATC will request MISO's Expedited Project Review (EPR) Process to include this project in MTEP24 App A

# Communications Reliability Program (CRP) Projects - 2024 & Beyond

- **Challenges, Trends & Opportunities**
  - Telecom Carrier Performance & Service Challenges
  - Future Substation Technology & Communication Demands
  - T-Line Asset Management & System Planning Alignment

# Distribution to Transmission (D-T) Interconnections

**120 requests in 2023**


- Governing documents:
  - FERC Tariff Attachment FF-ATCLLC
  - NERC Standards
  - FERC Filed D-T Interconnection Agreement (IA)
  - ATC's Load Interconnection Guide
  - ATC's Business Practices

# D-T Best Value Planning (BVP) Process


- Collaborative planning assessment to determine the best value solution for all parties
- Types of requests
  - New distribution substation
  - Distribution substation equipment change
  - Distributed energy resources (DERs)
  - Unforecasted load or change in load characteristics
  - Economic development projects
  - Power quality issues
- Individual Project Timelines Vary Widely

# D-T Dashboard

220 Active Projects




D-T Interconnection Requests by Year Including Distributed Energy Resources (DER)



# MISO Generation Interconnections Process

## Generator Interconnection Process

Study Cycle	Projects	MW
DPP-2017	13	2,100
DPP-2018	10	870
DPP-2019	16	1,700
DPP-2020	29	3,850
DPP-2021	38	5,200
DPP-2022	30	4,050




- DPP-2019 (and earlier) GIA Complete
- DPP-2020 GIAs in Progress
- DPP-2021 and DPP-2022 in Study
- DPP-2023 applications in March of 2024

Refer to full GI Process Flow Diagram and notes for more detail: [GI Application and DPP Readiness](#)



# G-T Project Dashboard



Active MISO GT Projects

**120**

Developers

**41**

Total MWs in Queue

**16.68K**

- Solar - 9.2 GW
- Storage - 4.5 GW
- Gas - 1.7 GW
- Wind - 1.3 GW



# ATC's Asset Renewal strategy is about balancing Performance Risk and Life Cycle Costs – Justin Nettesheim



# Asset Renewal Program Objectives


- Safety – public and worker
- Minimize total life cycle cost [Net Present Value of Revenue Requirements (NPV RR) from customer cost/rate perspective]
- Compliance
- Manage risk
- Reliable performance – maintain or improvement
- Environmental performance improvements
- Coordination with Stakeholders

# Replacement is based on...


## (Hint: Not Age!)

- Safety – public and worker
- Condition – tests, maintenance costs/risks
- Obsolescence – part availability, factory support, craft labor expertise with this specific equipment, available spares
- Utilization – application, system changes
- Criticality – consequence of failure, outage impacts
- Costs – maintenance and replacement
- Environmental – PCB contamination, oil volumes and containment, proximity to waterways, SF6 gas leaks, lead, mercury, environmental compliance/risks
- Compliance – NERC, CIP, EPA, State DNR
- Other Considerations – test frequency, on-line monitoring, test information available, fleet size, common fleet issues, maintenance history, failure mode, industry experience

## 2002- 2023 Forced Outages




### 2010 - 2023 Fair Weather/Storm Outage Comparison




# Reliability Performance: January - December 2023

## Customer Impact




The 4.07 T-SAIDI YTD is 2.86 minutes less than our five year average of 6.93 minutes.



The 0.041 T-SAIFI YTD is 0.021 less than our five year average of .062.

## Total Forced Outages




The 241 total Forced Outages YTD are 75 less than our five year average of 316.

## 2023 Top impacting outages:


Failed static wire and pole on circuit Y-51 due to snow, ice and high winds impacted 2 delivery points (4,576 customers) for 16.4 hours. This accounted for 0.68 T-SAIDI minutes (17%) of the 4.07 T-SAIDI minutes YTD.

Two uprooted trees on circuit 6740 (Sagola Tap) impacted 2 delivery points (1453 customers) for 13.5 hours. This accounted for 0.43 T-SAIDI minutes (11%) of the 4.07 T-SAIDI minutes YTD.

## Total Circuit Outages by Cause & Sub Cause



# Circuit Breakers Age Distribution




EquipmentSubType	Age <10	Age 11-20	Age 21-30	Age 31-40	Age 41-50	Age 51-60	Age >60
OilBreakers				40	85	79	
SF6GasBreakers	729	914	481	97	15		
VacuumBreakers				1			
<b>Total</b>	<b>729</b>	<b>914</b>	<b>481</b>	<b>138</b>	<b>100</b>	<b>79</b>	

## Number of Breakers in Fleet

**785** 69 kV  
**1413** 115/138/161 kV  
**238** 230/345 kV  
**2441** Total

# Presque Isle Switchyard – Breaker Asset Renewal




- Part of oil circuit breaker program to remove OCBs off system by 2029.
- Hydraulic Operating Mechanism is high maintenance and prone to leaks
- parts are no longer manufactured and limited field support
- HV bushings are at end of reliable life
- Microprocessor relays at end of life.
- Disconnect switches prone to difficult operation and at end of life.




# Overhead Transmission Lines – Wood Pole Lines 20-year Outlook

- Objective is to manage condition and preserve reliability and safety as these assets reach end of life.
- Pre-1980 vintage wood poles are likely to be replaced in the next 20 - 25 years.



# Overhead Transmission Lines – Steel Lattice Lines – Preliminary 20-year Outlook


- Objective is to manage condition and preserve reliability and safety as these pre-1940's assets reach end of life.
- Pre-1940 vintage lattice tower structures are likely to be replaced in the next 20 - 25 years.



# Asset Renewal T-line Needs

## Example of Successful Project

- Portage – Dam Heights 69kV Rebuild (Line Y-16)
  - Project Background
    - ◆ Approximately 25 of miles of rebuild
  - Past Needs
    - ◆ Condition and Performance Issues
    - ◆ Replace 1910's vintage lattice structures
    - ◆ Outages: One of the most frequently outage ATC lines
      - ✓ On average about 4 outages per year
      - ✓ Need to update to avian friendly design
      - ✓ Improved lightning performance
  - Current status
    - ◆ Project went in-service Fall of 2017
    - ◆ One lightning outage since the new design went into service (Design 45kA strike, actual 192kA strike)



# Assessment Status – Ted Weber

- Next Steps

- Needs comments – due March 29, 2024
- Finalize needs – Early April
- Preliminary solutions meeting/presentation – May 13, 2024
- Finish sensitivity studies – May
- Develop new or revised scope and cost estimates – June
- ATC internal review/approval – August
- 2024 Assessment publication – November 4, 2024

# Contacts

Ted Weber (TYA)

Email: [tweber2@atcllc.com](mailto:tweber2@atcllc.com)

Matt Waldron (G-T and D-T)

Email: [mwaldron@atcllc.com](mailto:mwaldron@atcllc.com)

Justin Nettesheim (AR T-line)

Email: [jnettesheim@atcllc.com](mailto:jnettesheim@atcllc.com)

Matt Falkowski (Communications)

Email: [mfalkowski@atcllc.com](mailto:mfalkowski@atcllc.com)

Q&A

